


# C-635-6 Recirculating Heat Utilization Pump House



## Facility Overview Briefing

July 16, 2021

Reflects consultation with EPA and Kentucky in accordance with the Site Management Plan that occurred on July 12, 2021.

# Purpose


- The C-635-6 Recirculating Heat Utilization Pump House is a candidate for future demolition and disposal, contingent upon funding priorities.
- Listed in Appendix 6 of the Site Management Plan (SMP); requires consultation with EPA and Kentucky for CERCLA screening prior to demolition.
- This presentation is intended to serve as consultation, providing the basis for demolition and disposal of the aboveground structure outside of the FFA/CERCLA process.
- The remaining slab/soils will be subject to a future CERCLA evaluation under Geographical Area (GA) 17.



C-635-6 Facility Photo: 4/2021

# Construction History

- C-635-6 is located within the Paducah Site security fence, west of the C-335 process building.
- The facility was constructed in 1983.
- The facility is a structural steel building with asbestos cement corrugated panels (transite).
  - ❑ The structure has two sections partially separated by a concrete wall, each with separate points of entry.
    - Pump house section
    - Transformer electrical switchgear section
- The entire facility is approximately 2,371 ft<sup>2</sup>.
  - ❑ The pump house section of the facility is approximately 1,846 ft<sup>2</sup>
    - Contains a subgrade area measuring ~26 ft x ~71 ft x ~7.5 ft.
    - Contains six floor drains that drain into a main sump.
    - Above ground portion measuring ~26 ft x ~71 ft.
  - ❑ The transformer with electrical switchgear section of the facility is approximately 525 ft<sup>2</sup>
    - Above grade on a 6-inch slab.
    - Measuring ~15 ft x ~35 ft.



Floor Plan View: Excerpt from Engineering Drawing A5E-14179-0001\_0001\_0001\_U-018105, dated 1981

# Operational History

- C-635-6 was originally built and operated as a waste heat utilization pump house from its construction in 1983 to 2014.
  - ❑ Recirculating cooling water (RCW) received from the C-335 process building was pumped to heaters in various buildings and to a heat exchanger that was used to further heat make up water for the C-600 Steam Plant.
  - ❑ RCW was then returned to the C-635-2 cooling tower, cycled through the C-335 process building for cooling of the components, and then sent back to C-635-6 where the process was repeated.
  - ❑ The buildings heated by the C-635-6 waste heat RCW system included: C-100, C-101, C-102, C-200, C-400, C-710, C-720, and C-750.
  - ❑ The C-635-6 waste heat RCW system originally contained chromate until RCW was switched over to a phosphate inhibitor in the early 1990s.
  
- USEC leased the facility in the early 1990s and continued to use C-635-6 as a waste heat utilization pump house until enrichment operations ceased at C-335.
  
- C-635-6 transitioned from USEC to DOE in 2014.



Pump House Section - Subgrade



Transformer Electrical Switchgear System Section – Above Grade

# Operational History

➤ In 2014, a steam heat exchanger was added west of the C-400 Cleaning Building and tied into the plant's steam distribution system, resulting in a modification to C-635-6.

- ❑ The C-635-6 waste heat utilization pump house was “blanked” (e.g., blocked) from the C-335 process building RCW system and converted to a closed-loop system.
- ❑ Heat was supplied off the C-600 steam system and recirculating heat system (RHS) water was pumped through C-635-6 to various buildings.
- ❑ The buildings supported by the modified C-635-6 RHS system included: C-100, C-101, C-102, C-200, C-710, and C-720 (Note: C-400 and C-750 were removed from the system).



Pump Discharge Header



C-335 Supply Header



Instrument Panel



Pump Control Panel



Expansion Tank

# Current Status

- C-635-6 remains operational, supplying heat to various buildings.
- Walkdown inspection conducted in April 2021 and employee interviews confirmed no unusual conditions.
  - ❑ Originally supplied heat to C-100, C-101, C-102, C-200, C-400, C-710, C-720, and C-750 (Note: C-400 and C-750 were later removed from the system).
  - ❑ Not used for radiological storage; facility does not contain any radiological postings.
  - ❑ No generator staging area (GSA) or satellite accumulation area (SAA).
  - ❑ Cement corrugated siding (transite).
  - ❑ Transformer with a 480-volt electrical switchgear.
    - Transformer is a dry-type transformer and does not contain any oil.
  - ❑ Six floor drains and a single sump are present.
  - ❑ Chromated water leaks have occurred within the facility; however, the water was returned to the RCW system via the floor drains which drained into the floor sump, where the chromated water was piped to a header return associated with the RCW system.
  - ❑ No known chemical spills except for the above noted chromated water leaks.




Floor Drain



Floor Sump

# Environmental Impacts (Solid Waste Management Units)



The C-635-6 Recirculating Heat Utilization Pump House is not designated as a SWMU/AOC.

SWMU No.	Facility Name	Current Status
059	NSDD (Inside)	Final CSOU
088	C-635 Pumphouse and Cooling Tower (slab and underlying soils)	Soils and Slabs OU
526	Internal Plant Drainage Ditches (includes KPDES 016)	SWOU Remedial Action

# Environmental Impacts

- No information to indicate a release or threatened release of a hazardous substance that would require an evaluation for a potential response action to protect future public health or welfare or the environment.
  - ❑ C-635-6 was built and operated as a waste heat utilization pump house that pumped recirculated water from the C-335 process building RCW system to buildings requiring heat from its construction in 1983 to 2014; C-635-6 was modified in 2014 to a closed-looped system and continues to supply heat to various buildings.
  - ❑ Building materials used for construction could contain lead-based paints and asbestos-containing materials, both of which can be effectively verified during a predemolition inspection and properly managed using standard demolition and waste management practices.
    - C-635-6 has cement corrugated siding (transite).
  - ❑ No history or records of chemical use or spills that would pose environmental release threat.
    - Chromated water leaks have occurred within the facility; however, the water was returned to the RCW system via the floor drains which drained into the floor sump, where the chromated water was piped to a header return associated with the RCW system.



# Conclusion and Recommendations


- Walkdown inspection of the facility, employee interviews, and other reviewed historical information did not identify any unusual conditions that would pose a potential threat of environmental release during future demolition of the aboveground structure.
  - ❑ Deactivation will include removal of any accessible loose items being stored (to the extent practicable) prior to demolition.
  - ❑ Any floor drains will be delineated, documented, and isolated prior to demolition.
- Pending ceasing of operation, deactivation, and availability of funding, proceeding with demolition and disposal of the C-635-6 facility (aboveground structure) outside of the FFA/CERCLA process, contingent upon the fact that no additional changes have occurred that would affect the CERCLA determination of the facility prior to demolition, is recommended.
- All applicable laws, regulations, and DOE procedures/protocols will be followed to ensure the demolition and disposal of the aboveground structure occurs in a safe, compliant manner, including conducting any additional radiological characterization through confirmation radiological surveys (as necessary) to support demolition and waste disposition.

# Conclusion and Recommendations


- As part of the demolition of the aboveground structure, the appropriate best management practices (BMPs) will be evaluated and implemented (as needed) to prevent/minimize the pooling and/or migration of storm water that may come into contact with any contamination that may exist on the pad/subsurface structure(s). For example, the following BMPs will be implemented as necessary:
  - ❑ Radiological surveying will occur following demolition.
  - ❑ Decontamination and/or application of fixatives and/or barriers to contaminated surfaces above regulatory posting limits.
  - ❑ Isolation measures and other types of barriers to minimize and/or control runoff/pooling of contaminated storm water (e.g., seal inlets to drains/sumps/subsurface structure(s)).
- Removal of the C-635-6 facility will be documented in the appropriate annual SMP revision.
- The future evaluation conducted for GA 17 will further evaluate the potential threat of release associated with the slab/soils from the C-635-6 facility.

## BACKUP INFORMATION


# C-635-6 Engineering Drawings



# C-635-6 Engineering Drawings



# C-635-6 Engineering Drawings



# C-635-6 Sources

- Engineering Drawings:
  - Provided in presentation
- Databases:
  - USEC's BPS
  - Issues Management System
  - Regulatory Compliance Archive Spill Log (pre-2018)
  - PCB Database (1989 – 2021)
  - Active GSAs and SAAs Master List
  - Asbestos Walkdown (October 2020)
- Employee Interviews:
  - Facility Manager (42 years plant expertise)
  - Utility Operations Subject Matter Expert (45 years plant expertise; operator/manager/supervisor)
  - Compliance Subject Matter Expert (45 years plant expertise; trained on system)
- Documents:
  - Paducah Gaseous Diffusion Plant Sitewide Strategy Facility Background Information, FPDP-RPT-0021, May 2016
  - Report for Environmental Audit Supporting Transition of the Gaseous Diffusion Plants to the United States Enrichment Corporation, DOE/OR/1087&V5 (June 1993)
  - Paducah Asbestos Survey Executive Summary (Lee Wan Report), October 1990