

VERIF. DATE: \_\_\_\_\_

INITIALS: \_\_\_\_\_

<b>CP4-ER-0020 FRev. 2</b>	<b>TITLE:</b> Control and Use of Pressure-Related Measuring and Test Equipment for the Northwest and Northeast Plume Operations	Page 1 of 10
<b>DOCUMENT CATEGORY:</b> <input type="checkbox"/> Administrative <input checked="" type="checkbox"/> Technical		
<b>LEVEL OF USE:</b> <input type="checkbox"/> Information Level <input checked="" type="checkbox"/> Reference Level <input type="checkbox"/> Continuous Use		
<b>FUNCTIONAL AREA:</b> Environmental Remediation <b>SUBJECT MATTER AREA:</b> Northwest and Northeast Plume Pump and Treat Operations	<b>SUBJECT MATTER EXPERT:</b> Fraser Johnstone – Technical Support	
<b>NUCLEAR SAFETY REVIEW DOCUMENTATION:</b> FRNP-21-0685-X	<b>APPROVED BY/DATE</b> (Signature on file): Joe Tarantino –Environmental Remediation Manager 9/29/2021	
<b>REQUIRED REVIEW DATE</b> (or expiration date for temporary change): 9/29/2024	<b>EFFECTIVE DATE:</b> 9/30/2021	

<b>REVISION/CHANGE LOG</b>			
Revision/Change Letter	Description of Changes	Pages Affected	Date of Revision/Change
FR0	Initial Bluesheeting	All	10/20/17
FR1	Non-Intent Revision to Incorporate Bluesheeting Changes and Update to Current Form	All	12/5/17
FR2	General revision for document review date.	All	9/29/21

<b>CP4-ER-0020</b> <b>FRev. 2</b>	<b>TITLE:</b> Control and Use of Pressure-Related Measuring and Test Equipment for the Northwest and Northeast Plume Operations	<b>Page 2 of 10</b>
--------------------------------------	---	---------------------

**TABLE OF CONTENTS**

1.0 PURPOSE AND SCOPE ..... 3

    1.1 Purpose..... 3

    1.2 Scope..... 3

2.0 REFERENCES..... 3

    2.1 Use References..... 3

    2.2 Source References..... 3

3.0 COMMITMENTS..... 4

4.0 PRECAUTIONS AND LIMITATIONS ..... 4

    4.1 Precautions ..... 4

    4.2 Limitations ..... 4

5.0 PREREQUISITES ..... 5

6.0 INSTRUCTIONS..... 5

    6.1 Calibration of Measuring and Test Equipment ..... 5

    6.2 Control of Measuring and Test Equipment ..... 5

    6.3 Verifying Accuracy of Installed Plant Instrumentation ..... 6

    6.4 Corrective Action ..... 7

    6.5 Handling and Storage of Measuring and Test Equipment ..... 7

    6.6 Status Indication of Installed Plant Instrumentation ..... 7

7.0 ACCEPTANCE CRITERIA ..... 7

8.0 POST PERFORMANCE WORK ACTIVITIES ..... 8

    8.1 Calibration of Measuring and Test Equipment Summary..... 8

9.0 RECORDS ..... 8

    9.1 Records Generated ..... 8

    9.2 Records Disposition ..... 9

APPENDIX A – ACRONYMS/DEFINITIONS ..... 10

<b>CP4-ER-0020</b> <b>FRev. 2</b>	<b>TITLE:</b> Control and Use of Pressure-Related Measuring and Test Equipment for the Northwest and Northeast Plume Operations	<b>Page 3 of 10</b>
--------------------------------------	--	---------------------

## 1.0 PURPOSE AND SCOPE

### 1.1 Purpose

This procedure outlines the control and use of Measuring and Test Equipment (M&TE) standards utilized at the Paducah Deactivation Project, Northwest and Northeast Plume (NWNEP) Operations facilities. M&TE standards include, but are **NOT** limited to, calibrated pressure gauges and manometers used to verify the accuracy of Installed Plant Instrumentation (IPI) used at the C-612, C-614, C-765, and C-765-A facilities.

### 1.2 Scope

This procedure describes steps for the control/use of M&TE standards utilized at the NWNEP facilities to support pressure-related calibration and testing activities identified in CP2-ER-0046, *Paducah Plume Operations Maintenance, Sampling and Analysis, and Calibration and Testing Plan*. These steps include M&TE standard requirements for calibration, pre-use inspection, control, handling, use, and storage requirements as well as corrective action requirements as a result of Out of Tolerance (OOT) IPI conditions.

## 2.0 REFERENCES

### 2.1 Use References

- CP2-ER-0012, *Waste Management Plan for the Pump-and-Treat Operations at the Paducah Gaseous Diffusion Plant, Paducah, Kentucky.*
- CP2-ER-0046, *Paducah Plume Operations Maintenance, Sampling and Analysis, and Calibration and Testing Plan*
- CP2-WM-0001, *Four Rivers Nuclear Partnership, LLC Paducah Deactivation and Remediation Project Waste Management Plan*
- CP3-RD-0010, *Records Management Process*
- CP3-SM-0017, *Measuring and Test Equipment*
- CP3-SM-0049, *Installed Plant Instrumentation Measuring and Test Equipment*

### 2.2 Source References

- CP2-QA-1000/FR2A, *Quality Assurance Program Description for the Paducah Gaseous Diffusion Plant, Paducah, Kentucky*
- CP3-OP-0025, *Document Control Process*
- DOE/LX/07-0339&D1, *Remedial Action Work Plan for the Northwest Plume Interim Remedial Action Optimization at the Paducah Gaseous Diffusion Plant, Paducah, Kentucky*
- DOE/LX/07-1280&D2/R3/A1, *Remedial Action Work Plan for Optimization of the Northeast Plume Interim Remedial Action at the Paducah Gaseous Diffusion Plant, Paducah, Kentucky*
- DOE/OR/07-1253&D4/R7, *Operation and Maintenance Plan for the Northwest Plume Groundwater System Interim Remedial Action at the Paducah Gaseous Diffusion Plant, Paducah, Kentucky*
- DOE/OR/07-1535&D3/R8, *Operation and Maintenance Plan for the Northeast Plume Containment System Interim Remedial Action at the Paducah Gaseous Diffusion Plant, Paducah, Kentucky*

<b>CP4-ER-0020</b> <b>FRev. 2</b>	<b>TITLE:</b> Control and Use of Pressure-Related Measuring and Test Equipment for the Northwest and Northeast Plume Operations	<b>Page 4 of 10</b>
--------------------------------------	--	---------------------

- DOE G 414.1-1C, *Management and Independent Assessments Guide*
- JHA-10844, *Maintenance, Operations, and Testing for the Northwest and Northeast Plume and Water Treatment Operations*

### 3.0 COMMITMENTS

None

### 4.0 PRECAUTIONS AND LIMITATIONS

#### 4.1 Precautions

**4.1.1** Personnel shall be made familiar with the hazards associated with exposure to Trichloroethylene (TCE) and review Safety Data Sheet.

**4.1.2** **When** opening **and** closing the Air Stripper Disconnect to be Locked Out, **then** the following shall be followed to protect from Arc Flash:

- Non-Essential personnel will stay clear while disconnect is being opened.
- Only trained and approved personnel will operate disconnect.
- Personnel operating disconnect should **NOT** stand in front of or directly face the disconnect when operating.
- Personnel performing work will wear appropriate Personal Protective Equipment (PPE) according to NFPA 70E, including safety glasses and long sleeves.

#### 4.2 Limitations

**4.2.1** The M&TE standards are utilized to verify the accuracy of IPI identified in CP2-ER-0046.

**4.2.2** Waste (Spill clean-up residues, pumps , other equipment, PPE) generated through the use of this procedure will be managed according to CP2-WM-0001, *Four Rivers Nuclear Partnership, LLC Paducah Deactivation and Remediation Project Waste Management Plan* and CP2-ER-0012, *Waste Management Plan for the Pump-and-Treat Operations at the Paducah Gaseous Diffusion Plant, Paducah, Kentucky*.

<b>CP4-ER-0020</b> <b>FRev. 2</b>	<b>TITLE:</b> Control and Use of Pressure-Related Measuring and Test Equipment for the Northwest and Northeast Plume Operations	<b>Page 5 of 10</b>
--------------------------------------	--	---------------------

## 5.0 PREREQUISITES

Obtain the following PPE as described:

- Safety Glasses with Side Shields.
- Steel toe safety boots.
- If more than incidental body contact with TCE contaminated liquid or material is expected then Tychem 5000 Apron and Sleeves or Silver Shield Apron and sleeves are required.
- PPE as specified by Radiological Work Permit and/or Radiological Protection/Industrial Hygiene.
- Respiratory Protection as specified by Industrial Hygiene/Radiological Control.
- When handling TCE contaminated pumps, piping, or liquid then wear TCE compatible gloves (as necessary) - Supreno EC Mircoflex Nitrile, Showa 730, or equivalent approved glove from Industrial Hygiene.

## 6.0 INSTRUCTIONS

### 6.1 Calibration of Measuring and Test Equipment

#### Calibration Technician

NOTE:

The method of calibration shall be based on the type of equipment, stability characteristics, required accuracy, intended use, and other conditions affecting performance.

Calibrate M&TE standards at prescribed intervals (for example annually) **and** whenever the accuracy of the M&TE standard is suspect in accordance with CP3-SM-0017, *Measuring and Test Equipment*.

### 6.2 Control of Measuring and Test Equipment

#### Operator

- 6.2.1** Prior to use, verify M&TE standard is **NOT** beyond its labeled calibration due date and inspect for signs of damage.
- 6.2.2** **If** M&TE standard is overdue for calibration **or** damage is discovered, **then** tag and segregate, **or** remove from service, **and DO NOT** use until it has been recalibrated, or request engineering authorization to continue use until such time as the equipment can be repaired or recalibrated.
- 6.2.3** Obtain replacement M&TE standard in accordance with CP3-SM-0017.

<b>CP4-ER-0020</b> <b>FRev. 2</b>	<b>TITLE:</b> Control and Use of Pressure-Related Measuring and Test Equipment for the Northwest and Northeast Plume Operations	<b>Page 6 of 10</b>
--------------------------------------	--	---------------------

### 6.3 Verifying Accuracy of Installed Plant Instrumentation

#### Operator

**NOTE:**

Available calibration and testing task forms for NWNPEP operations are as follows:

**NEPCS First Quarter:** CP2-ER-0046-F23, *NEPCS First Quarter Calibration and Testing Tasks*

**NEPCS Second Quarter:** CP2-ER-0046-F24, *NEPCS Second Quarter Calibration and Testing Tasks*

**NEPCS Third Quarter:** CP2-ER-0046-F25, *NEPCS Third Quarter Calibration and Testing Tasks*

**NEPCS Fourth Quarter:** CP2-ER-0046-F26, *NEPCS Fourth Quarter Calibration and Testing Tasks*

**NWPGS First Quarter (Even Year):** CP2-ER-0046-F30, *NWPGS First Quarter Even Year Quarterly Calibration and Testing Tasks*

**NWPGS First Quarter (Odd Year):** CP2-ER-0046-F34, *NWPGS First Quarter Odd Year Quarterly Calibration and Testing Tasks*

**NWPGS Second Quarter (Even Year):** CP2-ER-0046-F31, *NWPGS Second Quarter Even Year Quarterly Calibration and Testing Tasks*

**NWPGS Second Quarter (Odd Year):** CP2-ER-0046-F35, *NWPGS Second Quarter Odd Year Quarterly Calibration and Testing Tasks*

**NWPGS Third Quarter (Even Year):** CP2-ER-0046-F32, *NWPGS Third Quarter Even Year Quarterly Calibration and Testing Tasks*

**NWPGS Third Quarter (Odd Year):** CP2-ER-0046-F36, *NWPGS Third Quarter Odd Year Quarterly Calibration and Testing Tasks*

**NWPGS Fourth Quarter (Even Year):** CP2-ER-0046-F33, *NWPGS Fourth Quarter Even Year Quarterly Calibration and Testing Tasks*

**NWPGS Fourth Quarter (Odd Year):** CP2-ER-0046-F37, *NWPGS Fourth Quarter Odd Year Quarterly Calibration and Testing Tasks*

- 6.3.1** Obtain applicable Northeast Plume Containment System (NEPCS) or Northwest Plume Groundwater System (NWPGS) calibration and testing task form for the current operating quarter.

**NOTE:**

Inspection of the hand pneumatic pump will be conducted prior to use to ensure no damage is present.

- 6.3.2** Inspect hand pneumatic pump for damage prior to use. **If** damage to the pump is identified or pump is **NOT** functioning, **then** repair or replace the pump.
- 6.3.3** Connect the hand pneumatic pump **and** M&TE standard to the IPI device to be tested.
- 6.3.4** Pressurize the IPI device **and** M&TE standard using the hand pneumatic pump until M&TE standard reaches test pressure **and** compare the values displayed on the IPI device and M&TE standard.
- 6.3.5** Compare the results of the test to acceptable results identified on the calibration and testing forms referenced in CP2-ER-0046.

<b>CP4-ER-0020</b> <b>FRev. 2</b>	<b>TITLE:</b> Control and Use of Pressure-Related Measuring and Test Equipment for the Northwest and Northeast Plume Operations	<b>Page 7 of 10</b>
--------------------------------------	--	---------------------

**6.3.6** Document the results on the calibration and testing forms referenced in CP2-ER-0046.

**6.3.7** Document the M&TE number, serial number, calibration due date, and manufacturer of the M&TE standard, utilized during calibration and testing, in the comment section of the calibration and testing form.

**NOTE:**

Multiple test pressures may be required for the IPI device that is tested.

**6.3.8** Repeat Steps **6.3.4** through **6.3.7** until all test points have been completed for the specific IPI device.

**6.3.9** Initial **and** date the calibration and testing form referenced in CP2-ER-0046.

**6.3.10** Repeat Steps **6.3.3** through **6.3.9** until all IPI devices identified on the calibration and testing form requiring the use of an M&TE standard have been completed.

**6.3.11** Provide completed calibration and testing forms to supervisor for review.

**6.4 Corrective Action**

**Operator**

**6.4.1** If IPI devices, tested in accordance with CP2-ER-0046, are damaged **or** found to be OOT, **then** notify supervisor of equipment status.

**Performing Group Supervisor**

**6.4.2** Provide requisite notifications in accordance with CP3-SM-0049, *Installed Plant Instrumentation Measuring and Test Equipment* for each OOT IPI condition.

**6.5 Handling and Storage of Measuring and Test Equipment**

**Operator**

**6.5.1** Properly store and handle M&TE standards to maintain accuracy in accordance with manufacturer's specifications **or** guidance provided by engineering.

**6.5.2** Use M&TE standards in environments that are controlled to the extent necessary to ensure that the required accuracy and precision are maintained.

**6.6 Status Indication of Installed Plant Instrumentation**

**Operator**

Label IPI devices to indicate the calibration status **and** establish traceability to calibration records in accordance with CP3-SM-0049.

**7.0 ACCEPTANCE CRITERIA**

None

<b>CP4-ER-0020</b> <b>FRev. 2</b>	<b>TITLE:</b> Control and Use of Pressure-Related Measuring and Test Equipment for the Northwest and Northeast Plume Operations	<b>Page 8 of 10</b>
--------------------------------------	--	---------------------

## 8.0 POST PERFORMANCE WORK ACTIVITIES

### 8.1 Calibration of Measuring and Test Equipment Summary

#### Facility Manager

- 8.1.1** Maintain documentation showing the manufacturer, serial number, the date calibrated, calibration due date, **and** the facility performing the calibration for all M&TE utilized by Northeast and Northwest Plume Operations as required by procedure CP3-SM-0049.

#### NOTE:

Information submitted will include data necessary for interpretation of the calibration results and verification of compliance with applicable requirements.

- 8.1.2** Submit calibration certificates of M&TE to the Records Manager according to procedure CP3-RD-0010, *Records Management Process*.

## 9.0 RECORDS

### 9.1 Records Generated

The following records may be generated by this procedure:

- CP2-ER-0046-F23, *Northeast Plume Containment System First Quarter, Quarterly Calibration and Testing Task*
- CP2-ER-0046-F24, *Northeast Plume Containment System Second Quarter, Quarterly Calibration and Testing Task*
- CP2-ER-0046-F25, *Northeast Plume Containment System Third Quarter, Quarterly Calibration and Testing Task*
- CP2-ER-0046-F26, *Northeast Plume Containment System Fourth Quarter, Quarterly Calibration and Testing Task*
- CP2-ER-0046-F30, *Northwest Plume Containment System First Quarter Even Year, Quarterly Calibration and Testing Task*
- CP2-ER-0046-F31, *Northwest Plume Containment System Second Quarter Even Year, Quarterly Calibration and Testing Task*
- CP2-ER-0046-F32, *Northwest Plume Containment System Third Quarter Even Year, Quarterly Calibration and Testing Task*
- CP2-ER-0046-F33, *Northwest Plume Containment System Fourth Quarter Even Year, Quarterly Calibration and Testing Task*
- CP2-ER-0046-F34, *Northwest Plume Containment System First Quarter Odd Year, Quarterly Calibration and Testing Task*
- CP2-ER-0046-F35, *Northwest Plume Containment System Second Quarter Odd Year, Quarterly Calibration and Testing Task*



<b>CP4-ER-0020</b> <b>FRev. 2</b>	<b>TITLE:</b> Control and Use of Pressure-Related Measuring and Test Equipment for the Northwest and Northeast Plume Operations	<b>Page 9 of 10</b>
--------------------------------------	---	---------------------

- CP2-ER-0046-F36, *Northwest Plume Containment System Third Quarter Odd Year, Quarterly Calibration and Testing Task*
- CP2-ER-0046-F37, *Northwest Plume Containment System Fourth Quarter Odd Year, Quarterly Calibration and Testing Task*

Forms are to be completed in accordance with CP3-OP-0024, Forms Control.

## **9.2 Records Disposition**

The records are to be maintained in accordance with CP3-RD-0010.

<b>CP4-ER-0020</b> <b>FRev. 2</b>	<b>TITLE:</b> Control and Use of Pressure-Related Measuring and Test Equipment for the Northwest and Northeast Plume Operations	<b>Page 10 of 10</b>
--------------------------------------	---	----------------------

## **Appendix A – Acronyms/Definitions**

### **ACRONYMS**

**IPI** – Installed Plant Instrumentation

**M&TE** – Measuring and Test Equipment

**NEPCS** – Northeast Plume Containment System

**NWNEP** – Northwest Northeast Plumes

**NWPGS** – Northwest Plume Groundwater System

**OOT** – Out of Tolerance

**PPE** – Personal Protective Equipment

**TCE** – Trichloroethylene

### **DEFINITIONS**

None

**CP2-ER-0046-F23  
NORTHEAST PLUME CONTAINMENT SYSTEM  
FIRST QUARTER YEAR \_\_\_\_ (Year)  
QUARTERLY CALIBRATION AND TESTING TASKS**

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
<u>EW-234</u> LT-270	EW Level Transmitter	2-point check using manual water level meter.	Readings should be within $\pm 0.5$ feet of manual water level reading.	Test 1 = ____ ft Test 2 = ____ ft				
		Inspect desiccant pack. (Performed every quarter)	Desiccant pack acceptable for continued use per manufacturer's specification.					
	EW E-STOP #1 Stop	Perform functional verification. Push E-stop button.	System shutdown occurs and autodialer callout.	Shutdown occur? ____ Autodialer callout? ____				
	LSHH-280	Turn EW vault sump OFF and manually trip High-High Level Switch	Obtain alarm on C-765 HMI and receive autodialer callout.	Alarm obtained? ____ Autodialer callout? ____				
	LSH-280	Turn EW vault sump in AUTO, add water, and verify High Level Switch turns on EW sump pump.	Ensure proper function.					LSH-280 and LSL-280 are tested together.

CP2-ER-0046-F23  
 NORTHEAST PLUME CONTAINMENT SYSTEM  
 FIRST QUARTER YEAR \_\_\_\_ (Year)  
 QUARTERLY CALIBRATION AND TESTING TASKS

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
<u>EW-234 (Continued)</u>	LSL-280 EW Sump Low Level Switch	Turn EW vault sump in AUTO, add water, and verify Low Level Switch turns off EW sump pump.	Ensure proper function.					LSH-280 and LSL-280 are tested together.
<u>PI-290</u>	Pressure Gauge	Check Calibration	Test Point 1: 0 psig ± 1 psi Test Point 2: 50 psig ± 3 psi Test Point 3: 100 psig ± 3 psi Test Point 4: 150 psig ± 3 psi Test Point 5: 190 psig ± 3 psi	Test 1 = _____ psi Test 2 = _____ psi Test 3 = _____ psi Test 4 = _____ psi Test 5 = _____ psi				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
<u>C-765</u>	Pressure Gauge	Shutdown system, bleed pressure, and check for zero shift. Remove pressure gauge for testing if necessary. Perform only in odd year	Zero shift less than 5 psig.	Test = _____ psig				

CP2-ER-0046-F23  
 NORTHEAST PLUME CONTAINMENT SYSTEM  
 FIRST QUARTER YEAR \_\_\_\_ (Year)  
 QUARTERLY CALIBRATION AND TESTING TASKS

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
<u>C-765 (Continued)</u> P1-2	Pressure Gauge	Shutdown system, bleed pressure, and check for zero shift. Remove pressure gauge for testing if necessary. Perform only in odd year	Zero shift less than 5 psig.	Test = _____psig				
P1-3	Pressure Gauge	Shutdown system, bleed pressure, and check for zero shift. Remove pressure gauge for testing if necessary. Perform only in odd year	Zero shift less than 5 psig.	Test = _____psig				

**CP2-ER-0046-F23  
NORTHEAST PLUME CONTAINMENT SYSTEM  
FIRST QUARTER YEAR \_\_\_\_ (Year)  
QUARTERLY CALIBRATION AND TESTING TASKS**

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
<u>EW-235</u> LT-270	EW Level Transmitter	2-point check using manual water level meter.	Readings should be within $\pm 0.5$ feet of manual water level reading.	Test 1 = ____ ft Test 2 = ____ ft				
		Inspect desiccant pack. (Performed every quarter)	Desiccant pack acceptable for continued use per manufacturer's specification.					
<u>EW E-STOP #1</u>	Emergency Stop	Perform functional verification. Push E-stop button.	System shutdown occurs and autodialer callout.	Shutdown occur? ____ Autodialer callout? ____				
<u>LSHH-280</u>	EW Sump High-High Level Switch	Turn EW vault sump OFF and manually trip High-High Level Switch	Obtain alarm on C-765-A HMI and receive autodialer callout.	Alarm obtained? ____ Autodialer callout? ____				
<u>LSH-280</u>	EW Sump High Level Switch	Turn EW vault sump in AUTO, add water, and verify High Level Switch turns on EW sump pump.	Ensure proper function.					LSH-280 and LSL-280 are tested together.

**CP2-ER-0046-F23**  
**NORTHEAST PLUME CONTAINMENT SYSTEM**  
**FIRST QUARTER YEAR \_\_\_\_\_ (Year)**  
**QUARTERLY CALIBRATION AND TESTING TASKS**

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
<b>EW-235 (Continued)</b> LSL-280	EW Sump Low Level Switch	Turn EW vault sump in AUTO, add water, and verify Low Level Switch turns off EW sump pump.	Ensure proper function.					LSH-280 and LSL-280 are tested together.
PI-290	Pressure Gauge	Check Calibration	Test Point 1: 0 psig ± 1 psi Test Point 2: 50 psig ± 3 psi Test Point 3: 100 psig ± 3 psi Test Point 4: 150 psig ± 3 psi Test Point 5: 190 psig ± 3 psi	Test 1 = _____ psi Test 2 = _____ psi Test 3 = _____ psi Test 4 = _____ psi Test 5 = _____ psi				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
<b>C-765-A</b> PI-1	Pressure Gauge	Shutdown system, bleed pressure, and check for zero shift. Remove pressure gauge for testing if necessary. Perform only in odd year	Zero shift less than 5 psig.	Test = _____ psig				

CP2-ER-0046-F23  
 NORTHEAST PLUME CONTAINMENT SYSTEM  
 FIRST QUARTER YEAR \_\_\_\_ (Year)  
 QUARTERLY CALIBRATION AND TESTING TASKS

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
<u>C-765-A (Continued)</u> P1-2	Pressure Gauge	Shutdown system, bleed pressure, and check for zero shift. Remove pressure gauge for testing if necessary. Perform only in odd year	Zero shift less than 5 psig.	Test = _____psig				
P1-3	Pressure Gauge	Shutdown system, bleed pressure, and check for zero shift. Remove pressure gauge for testing if necessary. Perform only in odd year	Zero shift less than 5 psig.	Test = _____psig				

Reviewer \_\_\_\_\_ Date \_\_\_\_\_



CP2-ER-0046-F24  
 NORTHEAST PLUME CONTAINMENT SYSTEM  
 SECOND QUARTER YEAR \_\_\_\_ (Year)  
 QUARTERLY CALIBRATION AND TESTING TASKS

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
<u>EW-234</u> LT-270	EW Level Transmitter	Inspect desiccant pack. (Performed every quarter)	Desiccant pack acceptable for continued use per manufacturer's specification.					
N/A	POINT I/O EtherNet/IP Adapter	Turn off main disconnect at extraction well (EW) to interrupt communication with TU.	Obtain alarm on C-765 HMI and receive autodialer callout.	Alarm obtained? _____ Autodialer callout? _____				
<u>C-765</u>	Pressure Gauge	Shutdown system, bleed pressure, and check for zero shift. Remove pressure gauge for testing if necessary. Perform only in odd year	Zero shift less than 5 psig.	Test = _____psig				

CP2-ER-0046-F24  
 NORTHEAST PLUME CONTAINMENT SYSTEM  
 SECOND QUARTER YEAR \_\_\_\_ (Year)  
 QUARTERLY CALIBRATION AND TESTING TASKS

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
PI-5	Pressure Gauge	Shutdown system, bleed pressure, and check for zero shift. Remove pressure gauge for testing if necessary. Perform only in odd year	Zero shift less than 5 psig.	Test = _____psig				
PI-6	Pressure Gauge	Shutdown system, bleed pressure, and check for zero shift. Remove pressure gauge for testing if necessary. Perform only in odd year	Zero shift less than 5 psig.	Test = _____psig				
PI-13	Pressure Gauge	Shutdown system, bleed pressure, and check for zero shift. Remove pressure gauge for testing if necessary. Perform only in odd year	Zero shift less than 5 psig.	Test = _____psig				

C-765 (Continued)

**CP2-ER-0046-F24  
NORTHEAST PLUME CONTAINMENT SYSTEM  
SECOND QUARTER YEAR \_\_\_\_ (Year)  
QUARTERLY CALIBRATION AND TESTING TASKS**

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
<u>C-765 (Continued)</u> PI-14	Pressure Gauge	Shutdown system, bleed pressure, and check for zero shift. Remove pressure gauge for testing if necessary. Perform only in odd year	Zero shift less than 5 psig.	Test = _____psig				
N/A	Programmable Logic Controller (PLC)	Turn off main disconnect at treatment unit (TU) to interrupt power to the PLC.	Shutdown EW, obtain alarm on C-765 HMI and receive autodialer callout.	EW shutdown? _____ Autodialer callout? _____				
FIT-320	Treatment Unit Influent Flow Meter	Simulate flow from EW until flow rate is outside system operating range and alarm trip points.	EW shutdown and low/high flow alarm on HMI.	EW shutdown? _____ Low and High flow alarm obtained? _____				
TU E-STOP #1	Emergency Stop	Perform functional verification. Push E-stop button.	System shutdown occurs and autodialer callout.	Shutdown occur? _____ Autodialer callout? _____				

**CP2-ER-0046-F24**  
**NORTHEAST PLUME CONTAINMENT SYSTEM**  
**SECOND QUARTER YEAR \_\_\_\_\_ (Year)**  
**QUARTERLY CALIBRATION AND TESTING TASKS**

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
<u>C-765 (Continued)</u> TU E-STOP #2	Emergency Stop	Perform functional verification. Push E-stop button.	System shutdown occurs and autodialer callout.	Shutdown occur? _____ Autodialer callout?_____				
C-765 Air Compressor	Air compressor Tank	Drain condensate from air compressor receiver tank	No liquid remains in receiver tank	N/A				
C-765 Air Stripper Blower B-340	Air Stripper Blower	Lubricate bearings on blower	None	N/A	N/A			

**CP2-ER-0046-F24  
NORTHEAST PLUME CONTAINMENT SYSTEM  
SECOND QUARTER YEAR \_\_\_\_ (Year)  
QUARTERLY CALIBRATION AND TESTING TASKS**

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
<u>EW-235</u> LT-270	EW Level Transmitter	Inspect desiccant pack. (Performed every quarter)	Desiccant pack acceptable for continued use per manufacturer's specification.					
N/A	POINT I/O EtherNet/IP Adapter	Turn off main disconnect at extraction well (EW) to interrupt communication with TU.	Obtain alarm on C-765-A HMI and receive autodialer callout.	Alarm obtained? _____ Autodialer callout? _____				
<u>C-765-A</u>	Pressure Gauge	Shutdown system, bleed pressure, and check for zero shift. Remove pressure gauge for testing if necessary. Perform only in odd year	Zero shift less than 5 psig.	Test = _____psig				

CP2-ER-0046-F24  
 NORTHEAST PLUME CONTAINMENT SYSTEM  
 SECOND QUARTER YEAR \_\_\_\_ (Year)  
 QUARTERLY CALIBRATION AND TESTING TASKS

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
PI-5	Pressure Gauge	Shutdown system, bleed pressure, and check for zero shift. Remove pressure gauge for testing if necessary. Perform only in odd year	Zero shift less than 5 psig.	Test = _____psig				
PI-6	Pressure Gauge	Shutdown system, bleed pressure, and check for zero shift. Remove pressure gauge for testing if necessary. Perform only in odd year	Zero shift less than 5 psig.	Test = _____psig				
N/A	Programmable Logic Controller (PLC)	Turn off main disconnect at treatment unit (TU) to interrupt power to the PLC.	Shutdown EW, obtain alarm on C-765-A HMI and receive autodialer callout.	EW shutdown? _____ Autodialer callout? _____				

C-765-A (Continued)

**CP2-ER-0046-F24  
NORTHEAST PLUME CONTAINMENT SYSTEM  
SECOND QUARTER YEAR \_\_\_\_ (Year)  
QUARTERLY CALIBRATION AND TESTING TASKS**

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
<b>C-765-A (Continued)</b> FIT-320	Treatment Unit Influent Flow Meter	Simulate flow from EW until flow rate is below outside system operating range and alarm trip points.	EW shutdown and low/high flow alarm on HMI.	EW shutdown? _____ Low and High flow Alarm obtained? _____				
TU E-STOP #1	Emergency Stop	Perform functional verification. Push E-stop button.	System shutdown occurs and autodialer callout.	Shutdown occur? _____ Autodialer callout? _____				
TU E-STOP #2	Emergency Stop	Perform functional verification. Push E-stop button.	System shutdown occurs and autodialer callout.	Shutdown occur? _____ Autodialer callout? _____				

Reviewer \_\_\_\_\_ Date \_\_\_\_\_

CP2-ER-0046-F24  
 NORTHEAST PLUME CONTAINMENT SYSTEM  
 SECOND QUARTER YEAR \_\_\_\_ (Year)  
 QUARTERLY CALIBRATION AND TESTING TASKS

**C-765-A (Continued)**

C-765-A Air Compressor	Air compressor tank	Drain condensate from air compressor receiver tank	No liquid remains in receiver tank	N/A		
C-765 Air Stripper Blower B-340	Air Stripper Blower	Lubricate bearings on blower.	None	N/A	N/A	

Reviewer \_\_\_\_\_ Date \_\_\_\_\_



CP2-ER-0046-F25  
 NORTHEAST PLUME CONTAINMENT SYSTEM  
 THIRD QUARTER YEAR \_\_\_\_ (Year)  
 QUARTERLY CALIBRATION AND TESTING TASKS

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
<u>EW-234</u>	LT-270 EW Level Transmitter	Inspect desiccant pack. (Performed every quarter)	Desiccant pack acceptable for continued use per manufacturer's specification.					
<u>C-765</u> PI-7	Pressure Gauge	Shutdown system, bleed pressure, and check for zero shift. Remove pressure gauge for testing if necessary. Perform only in odd year	Zero shift less than 5 psig.	Test = _____ psig				
PI-8	Pressure Gauge	Shutdown system, bleed pressure, and check for zero shift. Remove pressure gauge for testing if necessary. Perform only in odd year	Zero shift less than 5 psig.	Test = _____ psig				

**CP2-ER-0046-F25  
NORTHEAST PLUME CONTAINMENT SYSTEM  
THIRD QUARTER YEAR \_\_\_\_ (Year)  
QUARTERLY CALIBRATION AND TESTING TASKS**

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
P1-9	Pressure Gauge	Shutdown system, bleed pressure, and check for zero shift. Remove pressure gauge for testing if necessary. Perform only in odd year	Zero shift less than 5 psig.	Test = _____ psig				
PT-310	Pressure Transducer	Check Calibration	Test Point 1: 0 psig + 3 psi Test Point 2: 50 psig ± 3 psi Test Point 3: 100psig ±3 psi Test Point 4: 150psig ±3 psi Test Point 5: 190psig ±3 psi  Obtain alarm on HMI	Test 1 = _____ psi Test 2 = _____ psi Test 3 = _____ psi Test 4 = _____ psi Test 5 = _____ psi  Alarm obtained? _____				Read point found on treatment unit HMI M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:  System alarm trip point is found in the "System set-up" menu on the HMI.

C-765 (Continued)

**CP2-ER-0046-F25  
NORTHEAST PLUME CONTAINMENT SYSTEM  
THIRD QUARTER YEAR \_\_\_\_ (Year)  
QUARTERLY CALIBRATION AND TESTING TASKS**

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
<u>C-765 (Continued)</u> PT-320	Pressure Transducer	Check Calibration	Test Point 1: 0 psig + 3 psi Test Point 2: 50 psig ± 3 psi Test Point 3: 100psig ±3 psi Test Point 4: 150psig ±3 psi Test Point 5: 190psig ±3 psi	Test 1 = _____ psi Test 2 = _____ psi Test 3 = _____ psi Test 4 = _____ psi Test 5 = _____ psi				Read point found on treatment unit HMI M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
		Isolate pressure transducer from system and add pressure until system alarm trip point.	Obtain High Pressure alarm on HMI.  PLC switches bag filter and indicates dirty filter on HMI.	Alarm _____ obtained?  Bag filter switch? _____  Dirty filter indicated? _____				System alarm trip point is found in the "System set-up" menu on the HMI. Differential pressure control across bag filters will change during this task.
PT-330	Pressure Transducer	Check Calibration	Test Point 1: 0 psig + 3psi Test Point 2: 50 psig ± 3 psi Test Point 3: 100psig ±3 psi Test Point 4: 150psig ±3 psi Test Point 5: 190psig ±3 psi	Test 1 = _____ psi Test 2 = _____ psi Test 3 = _____ psi Test 4 = _____ psi Test 5 = _____ psi				Read point found on treatment unit HMI M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:

**CP2-ER-0046-F25  
NORTHEAST PLUME CONTAINMENT SYSTEM  
THIRD QUARTER YEAR \_\_\_\_ (Year)  
QUARTERLY CALIBRATION AND TESTING TASKS**

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
<u>C-765 (Continued)</u> PT-360	Pressure Transducer	Check Calibration	Test Point 1: 0 psig + 3psi Test Point 2: 50 psig ± 3 psi Test Point 3: 100psig ±3 psi Test Point 4: 150psig ±3 psi Test Point 5: 190psig ±3 psi	Test 1 = _____ psi Test 2 = _____ psi Test 3 = _____ psi Test 4 = _____ psi Test 5 = _____ psi				Read point found on treatment unit HMI M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
PSH-340	Pressure Switch	Perform functional verification of switch by verifying switch activation against pressure gauge. Adjust setting as necessary.	Stop B-340 Blower at 30 in WC ±5 in WC and generates alarm on HMI	Blower shutdown pressure? _____ in WC Alarm obtained? _____				Maximum pressure applied to switch shall be less than 35 psig. M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:

CP2-ER-0046-F25  
 NORTHEAST PLUME CONTAINMENT SYSTEM  
 THIRD QUARTER YEAR \_\_\_\_ (Year)  
 QUARTERLY CALIBRATION AND TESTING TASKS

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
<u>EW-235</u>								
LT-270	EW Level Transmitter	Inspect desiccant pack. (Performed every quarter)	Desiccant pack acceptable for continued use per manufacturer's specification.					
<u>C-765-A</u>								
PI-7	Pressure Gauge	Shutdown system, bleed pressure, and check for zero shift. Remove pressure gauge for testing if necessary. Perform only in odd year	Zero shift less than 5 psig.	Test = _____ psig				
PI-8	Pressure Gauge	Shutdown system, bleed pressure, and check for zero shift. Remove pressure gauge for testing if necessary. Perform only in odd year	Zero shift less than 5 psig.	Test = _____ psig				

**CP2-ER-0046-F25  
NORTHEAST PLUME CONTAINMENT SYSTEM  
THIRD QUARTER YEAR \_\_\_\_ (Year)  
QUARTERLY CALIBRATION AND TESTING TASKS**

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
P1-9	Pressure Gauge	Shutdown system, bleed pressure, and check for zero shift. Remove pressure gauge for testing if necessary. Perform only in odd year	Zero shift less than 5 psig.	Test = _____ psig				
PT-310	Pressure Transducer	Check Calibration	Test Point 1: 0 psig + 3 psi Test Point 2: 50 psig ± 3 psi Test Point 3: 100psig ±3 psi Test Point 4: 150psig ±3 psi Test Point 5: 190psig ±3 psi  Obtain alarm on HMI	Test 1 = _____ psi Test 2 = _____ psi Test 3 = _____ psi Test 4 = _____ psi Test 5 = _____ psi  Alarm obtained? _____				Read point found on treatment unit HMI M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:  System alarm trip point is found in the "System set-up" menu on the HMI.

C-765-A (Continued)

**CP2-ER-0046-F25**  
**NORTHEAST PLUME CONTAINMENT SYSTEM**  
**THIRD QUARTER YEAR \_\_\_\_ (Year)**  
**QUARTERLY CALIBRATION AND TESTING TASKS**

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
PT-320	Pressure Transducer	Check Calibration	Test Point 1: 0 psig + 3 psi	Test 1 = _____ psi				Read point found on treatment unit HMI M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
			Test Point 2: 50 psig ± 3 psi	Test 2 = _____ psi				
			Test Point 3: 100psig ±3 psi	Test 3 = _____ psi				
			Test Point 4: 150psig ±3 psi	Test 4 = _____ psi				
			Test Point 5: 190psig ±3 psi	Test 5 = _____ psi				
		Isolate pressure transducer from system and add pressure until system alarm trip point.	Obtain High Pressure alarm on HMI.	Alarm obtained? _____				System alarm trip point is found in the "System set-up" menu on the HMI. Differential pressure control across bag filters will change during this task.
			PLC switches bag filter and indicates dirty filter on HMI.	Bag filter switch? _____				
				Dirty filter indicated? _____				
PT-330	Pressure Transducer	Check Calibration	Test Point 1: 0 psig + 3psi	Test 1 = _____ psi				Read point found on treatment unit HMI M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
			Test Point 2: 50 psig ± 3 psi	Test 2 = _____ psi				
			Test Point 3: 100psig ±3 psi	Test 3 = _____ psi				
			Test Point 4: 150psig ±3 psi	Test 4 = _____ psi				
			Test Point 5: 190psig ±3 psi	Test 5 = _____ psi				

**CP2-ER-0046-F25**  
**NORTHEAST PLUME CONTAINMENT SYSTEM**  
**THIRD QUARTER YEAR \_\_\_\_\_ (Year)**  
**QUARTERLY CALIBRATION AND TESTING TASKS**

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
<b>C-765-A (Continued)</b> PT-360	Pressure Transducer	Check Calibration	Test Point 1: 0 psig + 3psi Test Point 2: 50 psig ± 3 psi Test Point 3: 100psig ±3 psi Test Point 4: 150psig ±3 psi Test Point 5: 190psig ±3 psi	Test 1 = _____ psi Test 2 = _____ psi Test 3 = _____ psi Test 4 = _____ psi Test 5 = _____ psi				Read point found on treatment unit HMI M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
PSH-340	Pressure Switch	Perform functional verification of switch by verifying switch activation against pressure gauge. Adjust setting as necessary.	Stop B-340 Blower at 30 in WC ±5 in WC and generates alarm on HMI	Blower shutdown pressure? _____ in WC Alarm obtained? _____				Maximum pressure applied to switch shall be less than 35 psig. M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:

Reviewer \_\_\_\_\_ Date \_\_\_\_\_



**CP2-ER-0046-F26  
NORTHEAST PLUME CONTAINMENT SYSTEM  
FOURTH QUARTER YEAR \_\_\_\_\_ (Year)  
QUARTERLY CALIBRATION AND TESTING TASKS**

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
<u>EW-234</u>	LT-270 EW Level Transmitter	Inspect desiccant pack. (Performed every quarter)	Desiccant pack acceptable for continued use per manufacturer's specification.					
<u>C-765</u>	PI-10 Pressure Gauge	Shutdown system, bleed pressure, and check for zero shift. Remove pressure gauge for testing if necessary. Perform only in odd year	Zero shift less than 5 psig.	Test = _____ psig				
PI-11	Pressure Gauge	Shutdown system, bleed pressure, and check for zero shift. Remove pressure gauge for testing if necessary. Perform only in odd year	Zero shift less than 5 psig.	Test = _____ psig				

**CP2-ER-0046-F26  
NORTHEAST PLUME CONTAINMENT SYSTEM  
FOURTH QUARTER YEAR \_\_\_\_\_ (Year)  
QUARTERLY CALIBRATION AND TESTING TASKS**

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
<u>C-765 (Continued)</u> PI-12	Pressure Gauge	Shutdown system, bleed pressure, and check for zero shift. Remove pressure gauge for testing if necessary. Perform only in odd year	Zero shift less than 5 psig.	Test = _____ psig				
PSLL-340	Pressure Switch	Perform functional verification of switch by verifying switch activation against pressure gauge. Adjust setting as necessary.	Stop B-340 Blower at 5 inWC $\pm$ 2 inWC and generates alarm on HMI.	Blower shutdown pressure? _____ inWC Alarm obtained? _____				Maximum pressure applied to switch shall be less than 45 inWC. M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
DPT-340	Differential Pressure Gauge	Check Calibration	Test Point 1: 0 inWC + 2 inWC Test Point 2: 15 inWC $\pm$ 2 inWC Test Point 3: 25 inWC $\pm$ 2 inWC Test Point 4: 35 inWC $\pm$ 2 inWC Test Point 5: 45 inWC $\pm$ 2 inWC	Test 1 = _____ inWC Test 2 = _____ inWC Test 3 = _____ inWC Test 4 = _____ inWC Test 5 = _____ inWC				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:

**CP2-ER-0046-F26  
NORTHEAST PLUME CONTAINMENT SYSTEM  
FOURTH QUARTER YEAR \_\_\_\_\_ (Year)  
QUARTERLY CALIBRATION AND TESTING TASKS**

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>	
<b>C-765 (Continued)</b> DPT-350	Differential Pressure Transmitter	Check Calibration	Test Point 1: 0 inWC + 0.5 inWC Test Point 2: 6 inWC ± 1 inWC Test Point 3: 12 inWC ± 1 inWC Test Point 4: 18 inWC ± 1 inWC Test Point 5: 24 inWC ± 1 inWC	<b>HMI</b> Test 1 = _____ inWC Test 2 = _____ inWC Test 3 = _____ inWC Test 4 = _____ inWC Test 5 = _____ inWC					Read point found on treatment unit HMI and field local instrument. Record both values during calibration check. M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
				<b>Local</b> Test 1 = _____ inWC Test 2 = _____ inWC Test 3 = _____ inWC Test 4 = _____ inWC Test 5 = _____ inWC					
				Test 1 = _____ inWC Test 2 = _____ inWC Test 3 = _____ inWC Test 4 = _____ inWC Test 5 = _____ inWC					
				Test 1 = _____ inWC Test 2 = _____ inWC Test 3 = _____ inWC Test 4 = _____ inWC Test 5 = _____ inWC					
				Test 1 = _____ inWC Test 2 = _____ inWC Test 3 = _____ inWC Test 4 = _____ inWC Test 5 = _____ inWC					
				Test 1 = _____ inWC Test 2 = _____ inWC Test 3 = _____ inWC Test 4 = _____ inWC Test 5 = _____ inWC					
				Test 1 = _____ inWC Test 2 = _____ inWC Test 3 = _____ inWC Test 4 = _____ inWC Test 5 = _____ inWC					
				Test 1 = _____ inWC Test 2 = _____ inWC Test 3 = _____ inWC Test 4 = _____ inWC Test 5 = _____ inWC					
				Test 1 = _____ inWC Test 2 = _____ inWC Test 3 = _____ inWC Test 4 = _____ inWC Test 5 = _____ inWC					
				Test 1 = _____ inWC Test 2 = _____ inWC Test 3 = _____ inWC Test 4 = _____ inWC Test 5 = _____ inWC					
LIT-340	Level Indicator	Check Calibration	Test Point 1: 0 inWC + 1 inWC Test Point 2: 24 inWC ± 3 inWC Test Point 3: 48 inWC ± 3 inWC Test Point 4: 72 inWC ± 3 inWC Test Point 5: 96 inWC ± 3 inWC	Test 1 = _____ inWC Test 2 = _____ inWC Test 3 = _____ inWC Test 4 = _____ inWC Test 5 = _____ inWC				Read point found on treatment unit HMI. M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:	

**CP2-ER-0046-F26  
NORTHEAST PLUME CONTAINMENT SYSTEM  
FOURTH QUARTER YEAR \_\_\_\_\_ (Year)  
QUARTERLY CALIBRATION AND TESTING TASKS**

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
<b>C-765 (Continued)</b> LSLL-340	Level Switch	Remove water in air stripper sump until LSLL-340 activates.	Shutdown P-340 and obtain alarm on HMI.	P-340 shutdown? _____ Alarm obtained?				
LSHH-340	Level Switch	Add water in air stripper sump until LSHH-340 activates.	Shuts down EW, obtain alarm on HMI, and receive autodialer callout.	EW shutdown? _____ Alarm obtained? _____ Autodialer callout?				
LSHH-310	Level Switch	Shutdown treatment unit sump pump and fill sump with water until LSHH-310 activates.	Shuts down EW, obtain alarm on HMI, and receive autodialer callout.	EW shutdown? _____ Alarm obtained? _____ Autodialer callout?				Alarm delay is programmed in the PLC. LSHH-310 will not instantaneously alarm.

CP2-ER-0046-F26  
 NORTHEAST PLUME CONTAINMENT SYSTEM  
 FOURTH QUARTER YEAR \_\_\_\_ (Year)  
 QUARTERLY CALIBRATION AND TESTING TASKS

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
<u>EW-235</u>	EW Level Transmitter	Inspect desiccant pack. (Performed every quarter)	Desiccant pack acceptable for continued use per manufacturer's specification.					
<u>C-765-A</u>	Pressure Gauge	Shutdown system, bleed pressure, and check for zero shift. Remove pressure gauge for testing if necessary. Perform only in odd year	Zero shift less than 5 psig.	Test = _____ psig				
PI-11	Pressure Gauge	Shutdown system, bleed pressure, and check for zero shift. Remove pressure gauge for testing if necessary. Perform only in odd year	Zero shift less than 5 psig.	Test = _____ psig				

CP2-ER-0046-F26  
 NORTHEAST PLUME CONTAINMENT SYSTEM  
 FOURTH QUARTER YEAR \_\_\_\_ (Year)  
 QUARTERLY CALIBRATION AND TESTING TASKS

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
				Test = _____psig				
P1-12	Pressure Gauge	Shutdown system, bleed pressure, and check for zero shift. Remove pressure gauge for testing if necessary. Perform only in odd year	Zero shift less than 5 psig.					
PSLL-340	Pressure Switch	Perform functional verification of switch by verifying switch activation against pressure gauge. Adjust setting as necessary.	Stop B-340 Blower at 5 inWC $\pm 2$ inWC and generates alarm on HMI .	Blower shutdown pressure? _____inWC Alarm obtained? _____				Maximum pressure applied to switch shall be less than 45 inWC. M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:

C-765-A (Continued)

**CP2-ER-0046-F26  
NORTHEAST PLUME CONTAINMENT SYSTEM  
FOURTH QUARTER YEAR \_\_\_\_\_ (Year)  
QUARTERLY CALIBRATION AND TESTING TASKS**

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
<b>C-765-A (Continued)</b> DPT-340	Differential Pressure Gauge	Check Calibration	Test Point 1: 0 inWC + 0.5 inWC	HMI				Read point found on treatment unit HMI and field local instrument. Record both values during calibration check. M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
			Test Point 2: 6 inWC ± 1 inWC	Test 1 = _____ inWC				
			Test Point 3: 12 inWC ± 1 inWC	Test 2 = _____ inWC				
			Test Point 4: 18 inWC ± 1 inWC	Test 3 = _____ inWC				
			Test Point 5: 24 inWC ± 1 inWC	Test 4 = _____ inWC				
				Test 5 = _____ inWC				
LIT-340	Level Indicator	Check Calibration	Test Point 1: 0 inWC + 1 inWC	Local				Read point found on treatment unit HMI. M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
			Test Point 2: 24 inWC ± 3 inWC	Test 1 = _____ inWC				
			Test Point 3: 48 inWC ± 3 inWC	Test 2 = _____ inWC				
			Test Point 4: 72 inWC ± 3 inWC	Test 3 = _____ inWC				
			Test Point 5: 96 inWC ± 3 inWC	Test 4 = _____ inWC				
				Test 5 = _____ inWC				

**CP2-ER-0046-F26**  
**NORTHEAST PLUME CONTAINMENT SYSTEM**  
**FOURTH QUARTER YEAR \_\_\_\_\_ (Year)**  
**QUARTERLY CALIBRATION AND TESTING TASKS**

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
<b>C-765-A (Continued)</b> LSLL-340	Level Switch	Remove water in air stripper sump until LSLL-340 activates.	Shutdown P-340 and obtain alarm on HMI.	P-340 shutdown? _____ Alarm obtained?				
LSHH-340	Level Switch	Add water in air stripper sump until LSHH-340 activates.	Shuts down EW, obtain alarm on HMI, and receive autodialer callout.	EW shutdown? _____ Alarm obtained? _____ Autodialer callout?				
LSHH-310	Level Switch	Shutdown treatment unit sump pump and fill sump with water until LSHH-310 activates.	Shuts down EW, obtain alarm on HMI, and receive autodialer callout.	EW shutdown? _____ Alarm obtained? _____ Autodialer callout?				Alarm delay is programmed in the PLC. LSHH-310 will not instantaneously alarm.

Reviewer \_\_\_\_\_ Date \_\_\_\_\_



**CP2-ER-0046-F30  
NORTHWEST PLUME GROUNDWATER SYSTEM  
FIRST QUARTER EVEN YEAR \_\_\_\_\_  
QUARTERLY CALIBRATION AND TESTING TASKS**

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
<b><u>PRESSURE INDICATING GAUGES</u></b>								
PI-J003	Pressure Gauge @ EW- 230 Well Vault	Check calibration	Test 1 - Low point = 30 psi +/- 5 psi Test 2 - Oper. Point = 60 psi +/- 5 psi Test 3 - High point = 90 psi +/- 5 psi	Test 1 = _____ psi Test 2 = _____ psi Test 3 = _____ psi				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
PI-J004	Pressure Gauge @ EW- 231 Well Vault	Check calibration	Test 1 - Low point = 30 psi +/- 5 psi Test 2 - Oper. Point = 60 psi +/- 5 psi Test 3 - High point = 90 psi +/- 5 psi	Test 1 = _____ psi Test 2 = _____ psi Test 3 = _____ psi				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
PI-J010	Pressure Gauge @ EW- 233 Well Vault	Check calibration	Test 1 - Low point = 10 psi +/- 5 psi Test 2 - Oper. Point = 30 psi +/- 5 psi Test 3 - High point = 60 psi +/- 5 psi	Test 1 = _____ psi Test 2 = _____ psi Test 3 = _____ psi				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
PI-J011	Pressure Gauge @ EW- 233 Well Vault	Check calibration	Test 1 - Low point = 10 psi +/- 5 psi Test 2 - Oper. Point = 30 psi +/- 5 psi Test 3 - High point = 60 psi +/- 5 psi	Test 1 = _____ psi Test 2 = _____ psi Test 3 = _____ psi				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
PI-J005	Pressure Indicator @ Equalization Pump	Check calibration	Test 1 - Low point = 30 psi +/- 5 psi Test 2 - Oper. Point = 60 psi +/- 5 psi Test 3 - High point = 90 psi +/- 5 psi	Test 1 = _____ psi Test 2 = _____ psi Test 3 = _____ psi				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:

Reviewer \_\_\_\_\_ Date \_\_\_\_\_

**CP2-ER-0046-F30  
NORTHWEST PLUME GROUNDWATER SYSTEM  
FIRST QUARTER EVEN YEAR \_\_\_\_\_  
QUARTERLY CALIBRATION AND TESTING TASKS**

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
PI-AJ301	Pressure Indicator @ Air Stripper Blower	Check calibration	Test 1 - Verify/adjust to 0 inH2O Test 2 - High point = 28 inH2O +/- 2 inH2O	Test 1 = ___ inH2O Test 2 = ___ inH2O				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
PI-J306	Pressure Gauge @ Air Stripper Pump	Check calibration	Test 1 - Low point = 30 psi +/- 4 psi Test 2 - Oper. Point = 60 psi +/- 4 psi Test 3 - High point = 90 psi +/- 4 psi	Test 1 = ___ psi Test 2 = ___ psi Test 3 = ___ psi				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
PI-GPG-001	Pressure Gauge @ Sand Filter Number 1	Check calibration	Test 1 - Low point = 20 psi +/- 3 psi Test 2 - Oper. Point = 40 psi +/- 3 psi Test 3 - High point = 60 psi +/- 3 psi	Test 1 = ___ psi Test 2 = ___ psi Test 3 = ___ psi				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
PI-GPG-002	Pressure Gauge @ Sand Filter Number 1	Check calibration	Test 1 - Low point = 20 psi +/- 3 psi Test 2 - Oper. Point = 40 psi +/- 3 psi Test 3 - High point = 60 psi +/- 3 psi	Test 1 = ___ psi Test 2 = ___ psi Test 3 = ___ psi				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:

Reviewer \_\_\_\_\_ Date \_\_\_\_\_

**CP2-ER-0046-F30  
NORTHWEST PLUME GROUNDWATER SYSTEM  
FIRST QUARTER EVEN YEAR \_\_\_\_\_  
QUARTERLY CALIBRATION AND TESTING TASKS**

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
PI-GPG-003	Pressure Gauge @ Sand Filter Number 2	Check calibration	Test 1 - Low point = 20 psi +/- 3 psi Test 2 - Oper. Point = 40 psi +/- 3 psi Test 3 - High point = 60 psi +/- 3 psi	Test 1 = _____ psi Test 2 = _____ psi Test 3 = _____ psi				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
PI-GPG-004	Pressure Gauge @ Sand Filter Number 2	Check calibration	Test 1 - Low point = 20 psi +/- 3 psi Test 2 - Oper. Point = 40 psi +/- 3 psi Test 3 - High point = 60 psi +/- 3 psi	Test 1 = _____ psi Test 2 = _____ psi Test 3 = _____ psi				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
PI-2	Influent Pressure Gauge @ Ion Exchange Vessel A	Check calibration	Test 1 - Low point = 20 psi +/- 2 psi Test 2 - Oper. Point = 50 psi +/- 2 psi Test 3 - High point = 80 psi +/- 2 psi	Test 1 = _____ psi Test 2 = _____ psi Test 3 = _____ psi				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
PI-3	Effluent Pressure Gauge @ Ion Exchange Vessel A	Check calibration	Test 1 - Low point = 20 psi +/- 2 psi Test 2 - Oper. Point = 50 psi +/- 2 psi Test 3 - High point = 80 psi +/- 2 psi	Test 1 = _____ psi Test 2 = _____ psi Test 3 = _____ psi				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:

Reviewer \_\_\_\_\_ Date \_\_\_\_\_

**CP2-ER-0046-F30  
NORTHWEST PLUME GROUNDWATER SYSTEM  
FIRST QUARTER EVEN YEAR \_\_\_\_\_  
QUARTERLY CALIBRATION AND TESTING TASKS**

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
PI-4	Influent Pressure Gauge @ Ion Exchange Vessel B	Check calibration	Test 1 - Low point = 20 psi +/- 2 psi Test 2 - Oper. Point = 50 psi +/- 2 psi Test 3 - High point = 80 psi +/- 2 psi	Test 1 = _____ psi Test 2 = _____ psi Test 3 = _____ psi				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
PI-5	Effluent Pressure Gauge @ Ion Exchange Vessel B	Check calibration	Test 1 - Low point = 20 psi +/- 2 psi Test 2 - Oper. Point = 50 psi +/- 2 psi Test 3 - High point = 80 psi +/- 2 psi	Test 1 = _____ psi Test 2 = _____ psi Test 3 = _____ psi				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
PI-6	Influent Pressure Gauge @ Ion Exchange Vessel C	Check calibration	Test 1 - Low point = 20 psi +/- 2 psi Test 2 - Oper. Point = 50 psi +/- 2 psi Test 3 - High point = 80 psi +/- 2 psi	Test 1 = _____ psi Test 2 = _____ psi Test 3 = _____ psi				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
PI-7	Effluent Pressure Gauge @ Ion Exchange Vessel C	Check calibration	Test 1 - Low point = 20 psi +/- 2 psi Test 2 - Oper. Point = 50 psi +/- 2 psi Test 3 - High point = 80 psi +/- 2 psi	Test 1 = _____ psi Test 2 = _____ psi Test 3 = _____ psi				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
PI-8	Influent Pressure Gauge @ Ion Exchange Vessel D	Check calibration	Test 1 - Low point = 20 psi +/- 2 psi Test 2 - Oper. Point = 50 psi +/- 2 psi Test 3 - High point = 80 psi +/- 2 psi	Test 1 = _____ psi Test 2 = _____ psi Test 3 = _____ psi				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:

Reviewer \_\_\_\_\_ Date \_\_\_\_\_

**CP2-ER-0046-F30  
NORTHWEST PLUME GROUNDWATER SYSTEM  
FIRST QUARTER EVEN YEAR \_\_\_\_\_  
QUARTERLY CALIBRATION AND TESTING TASKS**

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
PI-9	Effluent Pressure Gauge @ Ion Exchange Vessel D	Check calibration	Test 1 - Low point = 20 psi +/- 2 psi Test 2 - Oper. Point = 50 psi +/- 2 psi Test 3 - High point = 80 psi +/- 2 psi	Test 1 = _____ psi Test 2 = _____ psi Test 3 = _____ psi				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:

**PRESSURE DIFFERENTIAL GAUGES**

PDIS-E301	Pressure Differential Gauge @ Air Stripper	Perform 2-point calibration	Test 1 - Verify/adjust to 0 inH2O Test 2 - High point = 14 inH2O +/- 2 in H2O	Test 1 = _____ in H2O Test 2 = _____ in H2O				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
-----------	--	-----------------------------	--	--	--	--	--	--

**INTERLOCKS**

I-27	Interlock	Perform functional verification	Test 1 - Upon system shutdown, UV-050 and UV-110 close	Test 1 = Did UV-050 and UV-110 close upon system shutdown? _____				
------	-----------	---------------------------------	--	--	--	--	--	--

Reviewer \_\_\_\_\_ Date \_\_\_\_\_

**CP2-ER-0046-F30  
NORTHWEST PLUME GROUNDWATER SYSTEM  
FIRST QUARTER EVEN YEAR \_\_\_\_\_  
QUARTERLY CALIBRATION AND TESTING TASKS**

**P&ID    ITEM    TASK    PASS/FAIL CRITERIA    READINGS    PASS/FAIL    DATE    OPERATOR    COMMENTS**

**ALARM CONDITIONS**

A-1	Alarm Condition 1	Perform functional verification	Test 1 - Equalization tank pump J-005 stops on system shutdown, alarm appears on PanelView, autodialer calls out	Test 1 = Did alarm appear on PanelView?  Did the autodialer call out? _____				
A-2	Alarm Condition 2	Perform functional verification	Test 1 - System shuts down when building sump level = 21 inches +/- 2 inches (high-high level switch); alarm appears on PanelView; autodialer calls out. Test 2 - System shuts down when trailer sump is full; alarm appears on PanelView; autodialer calls out.	Tests 1 and 2 = Did alarm appear on PanelView?  Did the autodialer call out? _____				
A-3	Alarm Condition 3	Perform functional verification	Test 1 - Leak alarm appears on PanelView when sensor is immersed in water; extraction wells shut down; autodialer calls out	Test 1 = Did alarm appear on PanelView when the LSH-008 sensor was immersed in water?  Did the autodialer call out? _____				

Reviewer \_\_\_\_\_ Date \_\_\_\_\_

**CP2-ER-0046-F31**  
**NORTHWEST PLUME GROUNDWATER SYSTEM**  
**SECOND QUARTER EVEN YEAR \_\_\_\_\_**  
**QUARTERLY CALIBRATION AND TESTING TASKS**

P&ID    ITEM    TASK    PASS/FAIL CRITERIA    READINGS    PASS/FAIL    DATE    OPERATOR    COMMENTS

**FLOW DEVICES**

FI-301	Flow Indicator @ Air Stripper	Calibrate flow meter	Test 1 - Oper. point = 0.29 inches H <sub>2</sub> O +/- 0.02 inches H <sub>2</sub> O	Test 1 = _____ in H <sub>2</sub> O				
--------	-------------------------------	----------------------	--	------------------------------------	--	--	--	--

**PRESSURE SAFETY DEVICES**

PSV-A6	Pressure Safety Valve @ Air Compressor Skid	Perform functional verification	Test 1 - Relief valve activates easily when pulled at the operating pressure	Verified at _____ psi				
--------	---	---------------------------------	--	-----------------------	--	--	--	--

**ALARM CONDITIONS**

A-1	Alarm Condition 1	Perform functional verification	Test 1 - Equalization tank pump J-005 stops on system shutdown, alarm appears on PanelView, autodialer calls out	Test 1 = Did alarm appear on PanelView? Did the autodialer call out?				
-----	-------------------	---------------------------------	--	---	--	--	--	--

Reviewer \_\_\_\_\_ Date \_\_\_\_\_

**CP2-ER-0046-F31**  
**NORTHWEST PLUME GROUNDWATER SYSTEM**  
**SECOND QUARTER EVEN YEAR \_\_\_\_\_**  
**QUARTERLY CALIBRATION AND TESTING TASKS**

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
A-2	Alarm Condition 2	Perform functional verification	Test 1 - System shuts down when sump level = 21 inches +/- 2 inches (high-high level switch); alarm appears on PanelView; autodialer calls out. Test 2 - System shuts down when trailer sump is full; alarm appears on PanelView; autodialer calls out	Tests 1 and 2 = Did alarm appear on PanelView? Did the autodialer call out? _____				
A-3	Alarm Condition 3	Perform functional verification	Test 1 - Leak alarm appears on PanelView when sensor is immersed in water; extraction wells shut down; autodialer calls out	Test 1 = Did alarm appear on PanelView when the LSH-008 sensor was immersed in water? Did the autodialer call out? _____				
A-4	Alarm Condition 4	Perform functional verification	Test 1 - When online analyzer detects effluent with >25 ppb TCE, alarm appears on PanelView; autodialer calls out	Test 1 = Did alarm appear on PanelView? Did the autodialer call out when TCE > 25 ppb? _____				

Reviewer \_\_\_\_\_ Date \_\_\_\_\_



**CP2-ER-0046-F32  
NORTHWEST PLUME GROUNDWATER SYSTEM  
THIRD QUARTER EVEN YEAR \_\_\_\_\_  
QUARTERLY CALIBRATION AND TESTING TASKS**

**P&ID    ITEM    TASK    PASS/FAIL CRITERIA    READINGS    PASS/FAIL    DATE    OPERATOR    COMMENTS**

**PRESSURE SWITCHES**

PSL/PSH- J003	EW-230 Well Perform Vault Pressure functional Switch High / verification Low	Test 1 - Low point = 35 psi +/- 5 psi; EW-230 shuts down; fault appears on PanelView Test 2 - High point = 75 psi +/- 5 psi; EW-230 shuts down; fault appears on PanelView	Test 1 = _____ psi  Test 2 = _____ psi					M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
PSL/PSH- J004	EW-231 Well Perform Vault Pressure functional Switch High / verification Low	Test 1 - Low point = 30 psi +/- 5 psi; EW-231 shuts down; fault appears on PanelView Test 2 - High point = 75 psi +/- 5 psi; EW-231 shuts down; fault appears on PanelView	Test 1 = _____ psi  Test 2 = _____ psi					M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
PSL/PSH- J010	EW-232 Well Perform Vault Pressure functional Switch High / verification Low	Test 1 - Low point = 10 psi +/- 5 psi; EW-232 shuts down; fault appears on PanelView Test 2 - High point = 60 psi +/- 5 psi; EW-232 shuts down; fault appears on PanelView	Test 1 = _____ psi  Test 2 = _____ psi					M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
PSL/PSH- J011	EW-233 Well Perform Vault Pressure functional Switch High / verification Low	Test 1 - Low point = 10 psi +/- 5 psi; EW-233 shuts down; fault appears on PanelView Test 2 - High point = 60 psi +/- 5 psi; EW-233 shuts down; fault appears on PanelView	Test 1 = _____ psi  Test 2 = _____ psi					M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:

Reviewer \_\_\_\_\_ Date \_\_\_\_\_

**CP2-ER-0046-F32  
NORTHWEST PLUME GROUNDWATER SYSTEM  
THIRD QUARTER EVEN YEAR \_\_\_\_\_  
QUARTERLY CALIBRATION AND TESTING TASKS**

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
PSL/PSH-AJ301	Air Stripper Blower Pressure Switch High / Low	Perform functional verification	Test 1 - System shuts down when blower discharge pressure (low pressure) = 8 inches H <sub>2</sub> O +/- 1 inches H <sub>2</sub> O; alarm appears on PanelView Test 2 - System shuts down when blower discharge pressure (high pressure) = 36 inches H <sub>2</sub> O +/- 3 inches H <sub>2</sub> O; alarm appears on PanelView	Test 1 = _____ in H <sub>2</sub> O  Test 2 = _____ in H <sub>2</sub> O				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:

**PRESSURE INDICATING GAUGES**

PI-J008	Pressure Gauge @ Backwash/ Sluice Pump	Check calibration	Test 1 - Low point = 15 psi +/- 3 psi Test 2 - Oper. Point = 30 psi +/- 3 psi Test 3 - High point = 45 psi +/- 3 psi	Test 1 = _____ psi Test 2 = _____ psi Test 3 = _____ psi				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
PI-J009A	Pressure Gauge @ Resin Dewatering Pump	Check calibration	Test 1 - Low point = 15 psi +/- 3 psi Test 2 - Oper. Point = 30 psi +/- 3 psi Test 3 - High point = 45 psi +/- 3 psi	Test 1 = _____ psi Test 2 = _____ psi Test 3 = _____ psi				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
PI-G003	Pressure Gauge @ Filter Press	Replace gauge	N/A	N/A	N/A			

Reviewer \_\_\_\_\_ Date \_\_\_\_\_

**CP2-ER-0046-F32  
NORTHWEST PLUME GROUNDWATER SYSTEM  
THIRD QUARTER EVEN YEAR \_\_\_\_\_  
QUARTERLY CALIBRATION AND TESTING TASKS**

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
PI-J012C	Pressure Indicator @ Air Compressor Skid	Check calibration	Test 1 - Low point = 50 psi +/- 6 psi Test 2 - Oper. Point = 100 psi +/- 4 psi Test 3 - High point = 125 psi +/- 4 psi	Test 1 = _____ psi Test 2 = _____ psi Test 3 = _____ psi				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:

**ALARM CONDITIONS**

A-1	Alarm Condition 1	Perform functional verification	Test 1 - Equalization tank pump J-005 stops on system shutdown, alarm appears on PanelView, autodialer calls out	Test 1 = Did alarm appear on PanelView? _____ Did the autodialer call out? _____				
A-2	Alarm Condition 2	Perform functional verification	Test 1 - System shuts down when sump level = 21 inches +/- 2 inches (high-high level switch); alarm appears on PanelView; autodialer calls out. Test 2 - System shuts down when tailer sump is full; alarm appears on PanelView; autodialer calls out	Tests 1 and 2 = Did alarm appear on PanelView? _____ Did the autodialer call out? _____				

Reviewer \_\_\_\_\_ Date \_\_\_\_\_

**CP2-ER-0046-F32**  
**NORTHWEST PLUME GROUNDWATER SYSTEM**  
**THIRD QUARTER EVEN YEAR \_\_\_\_\_**  
**QUARTERLY CALIBRATION AND TESTING TASKS**

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
A-3	Alarm Condition 3	Perform functional verification	Test 1 - Leak alarm appears on PanelView when sensor is immersed in water; extraction wells shut down; autodialer calls out	Test 1 = Did alarm appear on PanelView when the LSH-008 sensor was immersed in water?  Did the autodialer call out? _____				

Reviewer \_\_\_\_\_ Date \_\_\_\_\_

CP2-ER-0046-F33  
 NORTHWEST PLUME GROUNDWATER SYSTEM  
 FOURTH QUARTER EVEN YEAR  
 QUARTERLY CALIBRATION AND TESTING TASKS

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL (YES OR NO)</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
<b><u>LEVEL DEVICES</u></b>								
LE-F001	Level Probe @ Equalization Tank	Perform calibration	Test 1 - Low point = 5% +/- 1% Test 2 - High point = 90% +/- 1%	Test 1 = _____% Test 2 = _____%				
LE-E301	Level Probe @ Air Stripper	Perform calibration	Test 1 - Low point = 0% +/- 1% Test 2 - High point = 100% +/- 1%	Test 1 = _____% Test 2 = _____%				
L5H/L5L-E301	Level Switch High/Low @ Air Stripper	Perform functional verification	Test 1 - Alarm appears on PanelView when sump level = 95% +/- 5% Test 2 - Alarm appears on PanelView when sump level = 5% +/- 1%	Test 1 = _____% Test 2 = _____%				

Reviewer \_\_\_\_\_ Date \_\_\_\_\_

**CP2-ER-0046-F33**  
**NORTHWEST PLUME GROUNDWATER SYSTEM**  
**FOURTH QUARTER EVEN YEAR**  
**QUARTERLY CALIBRATION AND TESTING TASKS**

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL (YES OR NO)</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
LSL/LSH- J016	Level Switch Low / High @ Treatment System Sump	Perform functional verification	Test 1 - Sump pump J-016 starts on sump level = 16 inches +/- 2 inches (low level switch) Test 2 - Sump pump J-016 stops on sump level = 5 inches +/- 2 inches (high level switch)	Test 1 = _____ inches  Test 2 = _____ inches				
LSL/LSH- LSHH- F001	Level Switch Low / High @ Equalization Tank	Perform functional verification	Test 1a - Low point = 5% +/- 1% and equalization pump J-005 shuts down Test 1b - Equalization pump J-005 restarts when tank raises to 50% +/- 5% Test 2a - At 80% level in EQ tank, alarm on panel view Test 2b - At 80% level in EQ tank, alarm on panel view, all enabled pumps are turned off and all enabled wells restart at 75% Test 2c - High-high switch activates at 98% +/- 2%; alarm appears on PanelView, and equalization pump J-005 shuts down	Test 1a = _____ % Test 1b = _____ % Test 2a = _____ % Test 2b = _____ % Test 2c = _____ %				

Reviewer \_\_\_\_\_ Date \_\_\_\_\_

**CP2-ER-0046-F33**  
**NORTHWEST PLUME GROUNDWATER SYSTEM**  
**FOURTH QUARTER EVEN YEAR**  
**QUARTERLY CALIBRATION AND TESTING TASKS**

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL (YES OR NO)</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
LSLL/ LSH/ LSL/ LSHH- F002	Level Switch Low-Low / High / Low / High-High @ Backwash / Sluice Tank	Perform functional verification	Test 1 - Backwash pump J-008 stops when the backwash tank level reaches 5% +/- 2% (low-low switch) Test 2a - UV-50 opens and UV-110 closes when the backwash tank reaches 90% +/- 2% (high switch) Test 2b - UV-050 closes and UV-110 opens when the backwash tank reaches 80% +/- 2% (low switch) Test 3 - System shutdown occurs when the backwash tank reaches 98% +/- 2% (high-high switch); alarm appears on PanelView	Test 1 = _____ %  Test 2a = _____ %  Test 2b = _____ %  Test 3 = _____ %				
LSL/LSH/ LSHH- F008	Level Switch Low / High / High-High @ Settling Tank	Perform functional verification	Test 1 - Stop backwash pump J-008 on settling tank level = 95% +/- 2% (high-high level switch)	Test 1 = _____ %				

Reviewer \_\_\_\_\_ Date \_\_\_\_\_

CP2-ER-0046-F33  
 NORTHWEST PLUME GROUNDWATER SYSTEM  
 FOURTH QUARTER EVEN YEAR  
 QUARTERLY CALIBRATION AND TESTING TASKS

P&ID    ITEM    TASK    PASS/FAIL CRITERIA    READINGS    PASS/FAIL (YES OR NO)    DATE    OPERATOR    COMMENTS

INTERLOCKS

I-10	Interlock	Perform functional verification	Test 1 - Equalization tank pump J-005 stops on system shutdown, alarm appears on PanelView, autodialer calls out	Test 1 = Did pump stop when system was shut down? _____ Did autodialer call out? _____					
------	-----------	---------------------------------	--	--	--	--	--	--	--

ALARM CONDITIONS

A-1	Alarm Condition 1	Perform functional verification	Test 1 - Equalization tank pump J-005 stops on system shutdown, alarm appears on PanelView, autodialer calls out	Test 1 = Did alarm appear on PanelView? _____ Did the autodialer call out? _____					
A-2	Alarm Condition 2	Perform functional verification	Test 1 - System shuts down when sump level = 21 inches +/- 2 inches (high-high level switch); alarm appears on PanelView; autodialer calls out. Test 2 - System shuts down when trailer sump is full; alarm appears on PanelView; autodialer calls out	Tests 1 and 2 = Did alarm appear on PanelView? _____ Did the autodialer call out? _____					

Reviewer \_\_\_\_\_ Date \_\_\_\_\_



**CP2-ER-0046-F33**  
**NORTHWEST PLUME GROUNDWATER SYSTEM**  
**FOURTH QUARTER EVEN YEAR**  
**QUARTERLY CALIBRATION AND TESTING TASKS**

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL (YES OR NO)</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
A-3	Alarm Condition 3	Perform functional verification	Test 1 - Leak alarm appears on PanelView when sensor is immersed in water; extraction wells shut down; autodialer calls out	Test 1 = Did alarm appear on PanelView when the LSH-008 sensor was immersed in water?  Did the autodialer call out?				

Reviewer \_\_\_\_\_ Date \_\_\_\_\_

**CP2-ER-0046-F34  
NORTHWEST PLUME GROUNDWATER SYSTEM  
FIRST QUARTER ODD YEAR \_\_\_\_\_  
QUARTERLY CALIBRATION AND TESTING TASKS**

**P&ID      ITEM      TASK      PASS/FAIL CRITERIA      READINGS      PASS/FAIL (YES OR NO)      DATE      OPERATOR      COMMENTS**

**PRESSURE INDICATING GAUGES**

PI-J003	Pressure Gauge @ EW- 230 Well Vault	Check calibration	Test 1 - Low point = 30 psi +/- 5 psi Test 2 - Oper. Point = 60 psi +/- 5 psi Test 3 - High point = 90 psi +/- 5 psi	Test 1 = _____ psi Test 2 = _____ psi Test 3 = _____ psi				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
PI-J004	Pressure Gauge @ EW- 231 Well Vault	Check calibration	Test 1 - Low point = 30 psi +/- 5 psi Test 2 - Oper. Point = 60 psi +/- 5 psi Test 3 - High point = 90 psi +/- 5 psi	Test 1 = _____ psi Test 2 = _____ psi Test 3 = _____ psi				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
PI-J010	Pressure Gauge @ EW- 232 Well Vault	Check calibration	Test 1 - Low point = 10 psi +/- 5 psi Test 2 - Oper. Point = 30 psi +/- 5 psi Test 3 - High point = 60 psi +/- 5 psi	Test 1 = _____ psi Test 2 = _____ psi Test 3 = _____ psi				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
PI-J011	Pressure Gauge @ EW- 233 Well Vault	Check calibration	Test 1 - Low point = 10 psi +/- 5 psi Test 2 - Oper. Point = 30 psi +/- 5 psi Test 3 - High point = 60 psi +/- 5 psi	Test 1 = _____ psi Test 2 = _____ psi Test 3 = _____ psi				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
PI-J005	Pressure Indicator @ Equalization Pump	Check calibration	Test 1 - Low point = 30 psi +/- 5 psi Test 2 - Oper. Point = 60 psi +/- 5 psi Test 3 - High point = 90 psi +/- 5 psi	Test 1 = _____ psi Test 2 = _____ psi Test 3 = _____ psi				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:

Reviewer \_\_\_\_\_ Date \_\_\_\_\_

**CP2-ER-0046-F34  
NORTHWEST PLUME GROUNDWATER SYSTEM  
FIRST QUARTER ODD YEAR \_\_\_\_\_  
QUARTERLY CALIBRATION AND TESTING TASKS**

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL (YES OR NO)</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
PI-AJ301	Pressure Indicator @ Air Stripper Blower	Check calibration	Test 1 - Verify/adjust to 0 inH2O Test 2 - High point = 28 inH2O +/- 2 inH2O	Test 1 = ___ inH2O Test 2 = ___ inH2O				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
PI-J306	Pressure Gauge @ Air Stripper Pump	Check calibration	Test 1 - Low point = 30 psi +/- 5 psi Test 2 - Oper. Point = 60 psi +/- 5 psi Test 3 - High point = 90 psi +/- 5 psi	Test 1 = ___ psi Test 2 = ___ psi Test 3 = ___ psi				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
PI-GPG-001	Pressure Gauge @ Sand Filter Number 1	Check calibration	Test 1 - Low point = 20 psi +/- 3 psi Test 2 - Oper. Point = 40 psi +/- 3 psi Test 3 - High point = 60 psi +/- 3 psi	Test 1 = ___ psi Test 2 = ___ psi Test 3 = ___ psi				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
PI-GPG-002	Pressure Gauge @ Sand Filter Number 1	Check calibration	Test 1 - Low point = 20 psi +/- 3 psi Test 2 - Oper. Point = 40 psi +/- 3 psi Test 3 - High point = 60 psi +/- 3 psi	Test 1 = ___ psi Test 2 = ___ psi Test 3 = ___ psi				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:

Reviewer \_\_\_\_\_ Date \_\_\_\_\_

**CP2-ER-0046-F34  
NORTHWEST PLUME GROUNDWATER SYSTEM  
FIRST QUARTER ODD YEAR \_\_\_\_\_  
QUARTERLY CALIBRATION AND TESTING TASKS**

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL (YES OR NO)</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
PI-GPG-003	Pressure Gauge @ Sand Filter Number 1	Check calibration	Test 1 - Low point = 20 psi +/- 3 psi Test 2 - Oper. Point = 40 psi +/- 3 psi Test 3 - High point = 60 psi +/- 3 psi	Test 1 = _____ psi Test 2 = _____ psi Test 3 = _____ psi				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
	PI-GPG-004	Pressure Gauge @ Sand Filter Number 1	Check calibration	Test 1 - Low point = 20 psi +/- 3 psi Test 2 - Oper. Point = 40 psi +/- 3 psi Test 3 - High point = 60 psi +/- 3 psi	Test 1 = _____ psi Test 2 = _____ psi Test 3 = _____ psi			M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
		PI-2	Influent Pressure Gauge @ Ion Exchange Vessel A	Check calibration	Test 1 - Low point = 20 psi +/- 2 psi Test 2 - Oper. Point = 50 psi +/- 2 psi Test 3 - High point = 80 psi +/- 2 psi	Test 1 = _____ psi Test 2 = _____ psi Test 3 = _____ psi		
PI-3			Effluent Pressure Gauge @ Ion Exchange Vessel A	Check calibration	Test 1 - Low point = 20 psi +/- 2 psi Test 2 - Oper. Point = 50 psi +/- 2 psi Test 3 - High point = 80 psi +/- 2 psi	Test 1 = _____ psi Test 2 = _____ psi Test 3 = _____ psi		

Reviewer \_\_\_\_\_ Date \_\_\_\_\_

**CP2-ER-0046-F34  
NORTHWEST PLUME GROUNDWATER SYSTEM  
FIRST QUARTER ODD YEAR \_\_\_\_\_  
QUARTERLY CALIBRATION AND TESTING TASKS**

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL (YES OR NO)</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
PI-4	Influent Pressure Gauge @ Ion Exchange Vessel B	Check calibration	Test 1 - Low point = 20 psi +/- 2 psi Test 2 - Oper. Point = 50 psi +/- 2 psi Test 3 - High point = 80 psi +/- 2 psi	Test 1 = _____ psi Test 2 = _____ psi Test 3 = _____ psi				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
PI-5	Effluent Pressure Gauge @ Ion Exchange Vessel B	Check calibration	Test 1 - Low point = 20 psi +/- 2 psi Test 2 - Oper. Point = 50 psi +/- 2 psi Test 3 - High point = 80 psi +/- 2 psi	Test 1 = _____ psi Test 2 = _____ psi Test 3 = _____ psi				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
PI-6	Influent Pressure Gauge @ Ion Exchange Vessel C	Check calibration	Test 1 - Low point = 20 psi +/- 2 psi Test 2 - Oper. Point = 50 psi +/- 2 psi Test 3 - High point = 80 psi +/- 2 psi	Test 1 = _____ psi Test 2 = _____ psi Test 3 = _____ psi				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
PI-7	Effluent Pressure Gauge @ Ion Exchange Vessel C	Check calibration	Test 1 - Low point = 20 psi +/- 2 psi Test 2 - Oper. Point = 50 psi +/- 2 psi Test 3 - High point = 80 psi +/- 2 psi	Test 1 = _____ psi Test 2 = _____ psi Test 3 = _____ psi				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:

Reviewer \_\_\_\_\_ Date \_\_\_\_\_

**CP2-ER-0046-F34  
NORTHWEST PLUME GROUNDWATER SYSTEM  
FIRST QUARTER ODD YEAR \_\_\_\_\_  
QUARTERLY CALIBRATION AND TESTING TASKS**

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL (YES OR NO)</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
PI-8	Influent Pressure Gauge @ Ion Exchange Vessel D	Check calibration	Test 1 - Low point = 20 psi +/- 2 psi Test 2 - Oper. Point = 50 psi +/- 2 psi Test 3 - High point = 80 psi +/- 2 psi	Test 1 = _____ psi Test 2 = _____ psi Test 3 = _____ psi				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
PI-9	Effluent Pressure Gauge @ Ion Exchange Vessel D	Check calibration	Test 1 - Low point = 20 psi +/- 2 psi Test 2 - Oper. Point = 50 psi +/- 2 psi Test 3 - High point = 80 psi +/- 2 psi	Test 1 = _____ psi Test 2 = _____ psi Test 3 = _____ psi				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
<b><u>PRESSURE DIFFERENTIAL GAUGES</u></b>								
PDIS-E301	Pressure Differential Gauge @ Air Stripper	Perform 2-point calibration H2O	Test 1 - Verify/adjust to 0 inH2O Test 2 - High point = 14 inH2O +/- 2 in	Test 1 = _____ psi Test 2 = _____ psi				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
<b><u>INTERLOCKS</u></b>								
I-11	Interlock	Perform functional verification	Test 1 - Air stripper blower AJ-001 shuts down after 60 seconds +/- 10 seconds after the air stripper pump J-006 stops	Test 1 = _____ sec				

Reviewer \_\_\_\_\_ Date \_\_\_\_\_

**CP2-ER-0046-F34**  
**NORTHWEST PLUME GROUNDWATER SYSTEM**  
**FIRST QUARTER ODD YEAR \_\_\_\_\_**  
**QUARTERLY CALIBRATION AND TESTING TASKS**

P&ID    ITEM    TASK    PASS/FAIL CRITERIA    READINGS    PASS/FAIL (YES OR NO)    DATE    OPERATOR    COMMENTS

**ALARM CONDITIONS**

A-1	Alarm Condition 1	Perform functional verification	Test 1 - Equalization tank pump J-005 stops on system shutdown, alarm appears on PanelView, autodialer calls out	Test 1 = Did alarm appear on PanelView?  Did the autodialer call out?					
A-2	Alarm Condition 2	Perform functional verification	Test 1 - System shuts down when sump level = 21 inches +/- 2 inches (high-high level switch); alarm appears on PanelView; autodialer calls out. Test 2 - System shuts down when trailer sump is full; alarm appears on PanelView; autodialer calls out.	Tests 1 and 2 = Did alarm appear on PanelView?  Did the autodialer call out?					
A-3	Alarm Condition 3	Perform functional verification	Test 1 - Leak alarm appears on PanelView when sensor is immersed in water; extraction wells shut down; autodialer calls out	Test 1 = Did alarm appear on PanelView when the LSH-008 sensor was immersed in water?  Did the autodialer call out?					

Reviewer \_\_\_\_\_ Date \_\_\_\_\_

**CP2-ER-0046-F35  
 NORTHWEST PLUME GROUNDWATER SYSTEM  
 SECOND QUARTER ODD YEAR \_\_\_\_\_  
 QUARTERLY CALIBRATION AND TESTING TASKS**

**P&ID**    **ITEM**    **TASK**    **PASS/FAIL CRITERIA**    **READINGS**    **PASS/FAIL (YES OR NO)**    **DATE**    **OPERATOR**    **COMMENTS**

**PRESSURE SAFETY DEVICES**

PSV-A6	Pressure Safety Valve @ Air Compressor Skid	Perform functional verification	Test 1 - Relief valve activates easily when pulled at the operating pressure	Verified at _____ psi					
--------	---	---------------------------------	--	-----------------------	--	--	--	--	--

**INTERLOCKS**

I-16	Interlock	Perform functional verification	Test 1 - Air stripper heater AC-001 and air stripper blower AJ-001 shut down 60 seconds +/- 6 seconds after the air stripper pump J-006 shuts down. Verify air stripper heater shuts off with the air stripper blower.	Test 1 = _____ sec					
------	-----------	---------------------------------	--	--------------------	--	--	--	--	--

**ALARM CONDITIONS**

A-1	Alarm Condition 1	Perform functional verification	Test 1 - Equalization tank pump J-005 stops on system shutdown, alarm appears on PanelView, autodialer calls out	Test 1 = Did alarm appear on PanelView?  Did the autodialer call out?					
-----	-------------------	---------------------------------	--	---	--	--	--	--	--

Reviewer \_\_\_\_\_ Date \_\_\_\_\_



**CP2-ER-0046-F35**  
**NORTHWEST PLUME GROUNDWATER SYSTEM**  
**SECOND QUARTER ODD YEAR**  
**QUARTERLY CALIBRATION AND TESTING TASKS**

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL (YES OR NO)</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
A-2	Alarm Condition 2	Perform functional verification	Test 1 - System shuts down when sump level = 21 inches +/- 2 inches (high-high level switch); alarm appears on PanelView; autodialer calls out. Test 2 - System shuts down when trailer sump is full; alarm appears on PanelView; autodialer calls out	Tests 1 and 2 = Did alarm appear on PanelView? Did the autodialer call out?				
A-3	Alarm Condition 3	Perform functional verification	Test 1 - Leak alarm appears on PanelView when sensor is immersed in water; extraction wells shut down; autodialer calls out	Test 1 = Did alarm appear on PanelView when the LSH-008 sensor was immersed in water? Did the autodialer call out?				

Reviewer \_\_\_\_\_ Date \_\_\_\_\_

**CP2-ER-0046-F36  
NORTHWEST PLUME GROUNDWATER SYSTEM  
THIRD QUARTER ODD YEAR \_\_\_\_\_  
QUARTERLY CALIBRATION AND TESTING TASKS**

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL (YES OR NO)</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
-----------------	-------------	-------------	---------------------------	-----------------	----------------------------------	-------------	-----------------	-----------------

**PRESSURE SWITCHES**

PSL/PSH- J010	EW-232 Well Perform Vault Pressure functional Switch High / verification Low	Test 1 - Low point = 10 psi +/- 5 psi; EW-232 shuts down; fault appears on PanelView Test 2 - High point = 60 psi +/- 5 psi; EW-232 shuts down; fault appears on PanelView	Test 1 = _____ psi Test 2 = _____ psi					M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
------------------	---	---	--	--	--	--	--	--

PSL/PSH- J011	EW-233 Well Perform Vault Pressure functional Switch High / verification Low	Test 1 - Low point = 10 psi +/- 5 psi; EW-233 shuts down; fault appears on PanelView Test 2 - High point = 60 psi +/- 5 psi; EW-233 shuts down; fault appears on PanelView	Test 1 = _____ psi Test 2 = _____ psi					M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
------------------	---	---	--	--	--	--	--	--

PSL/PSH- AJ301	Air Stripper Blower Pressure Switch High / Low	Test 1 - System shuts down when blower discharge pressure (low pressure) = 8 inH2O +/- 1 inH2O; alarm appears on PanelView Test 2 - System shuts down when blower discharge pressure (high pressure) = 36 inH2O +/- 3 inH2O; alarm appears on PanelView	Test 1 = _____ in H <sub>2</sub> O Test 2 = _____ in H <sub>2</sub> O					M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
-------------------	--	--	--	--	--	--	--	--

**PRESSURE INDICATING GAUGES**

PI-J008	Pressure Gauge @ Backwash/ Sluice Pump	Test 1 - Low point = 15 psi +/- 3 psi Test 2 - Oper. Point = 30 psi +/- 3 psi Test 3 - High point = 45 psi +/- 3 psi	Test 1 = _____ psi Test 2 = _____ psi Test 3 = _____ psi					M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:
---------	---	--	--	--	--	--	--	--

Reviewer \_\_\_\_\_ Date \_\_\_\_\_

**CP2-ER-0046-F36  
NORTHWEST PLUME GROUNDWATER SYSTEM  
THIRD QUARTER ODD YEAR \_\_\_\_\_  
QUARTERLY CALIBRATION AND TESTING TASKS**

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL (YES OR NO)</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
PI-G003	Pressure Gauge @ Filter Press	Replace gauge	N/A	N/A	N/A			
PI-J012C	Pressure Indicator @ Air Compressor Skid	Check calibration	Test 1 - Low point = 50 psi +/- 6 psi Test 2 - Oper. Point = 100 psi +/- 4 psi Test 3 - High point = 125 psi +/- 4 psi	Test 1 = _____ psi Test 2 = _____ psi Test 3 = _____ psi				M&TE #: Manufacturer: Serial Number: Cal Due Date: Facility:

**INTERLOCKS**

I-17	Interlock	Perform functional verification	Test 1 - Upon system shutdown, the air stripper pump J-006 shuts down when the air stripper sump level reaches 10% +/- 2%	Test 1 = Did the J-006 shut down after system shutdown?				
I-50	Interlock	Perform functional verification	Test 1 - Upon operation of equalization tank pump J-005, the air stripper blower AJ-001 and air stripper heater AC-001 start running	Test 1 = Did AJ-001 and AC-001 start running when J-005 was operating?				

Reviewer \_\_\_\_\_ Date \_\_\_\_\_

**CP2-ER-0046-F36  
 NORTHWEST PLUME GROUNDWATER SYSTEM  
 THIRD QUARTER ODD YEAR \_\_\_\_\_  
 QUARTERLY CALIBRATION AND TESTING TASKS**

**P&ID    ITEM    TASK    PASS/FAIL CRITERIA    READINGS    PASS/FAIL (YES OR NO)    DATE    OPERATOR    COMMENTS**

**ALARM CONDITIONS**

A-1	Alarm Condition 1	Perform functional verification	Test 1 - Equalization tank pump J-005 stops on system shutdown, alarm appears on PanelView, autodialer calls out	Test 1 = Did alarm appear on PanelView?  Did the autodialer call out? _____					
A-2	Alarm Condition 2	Perform functional verification	Test 1 - System shuts down when sump level = 21 inches +/- 2 inches (high level switch); alarm appears on PanelView; autodialer calls out. Test 2 - System shuts down when trailer sump is full; alarm appears on Panel View; autodialer calls out	Tests 1 and 2 = Did alarm appear on PanelView?  Did the autodialer call out? _____					
A-3	Alarm Condition 3	Perform functional verification	Test 1 - Leak alarm appears on PanelView when sensor is immersed in water; extraction wells shut down; autodialer calls out	Test 1 = Did alarm appear on PanelView when the LSH-008 sensor was immersed in water?  Did the autodialer call out? _____					

Reviewer \_\_\_\_\_ Date \_\_\_\_\_

CP2-ER-0046-F37  
 NORTHWEST PLUME GROUNDWATER SYSTEM  
 FOURTH QUARTER ODD YEAR  
 QUARTERLY CALIBRATION AND TESTING TASKS

P&ID      ITEM      TASK      PASS/FAIL CRITERIA      READINGS      PASS/FAIL (YES OR NO)      DATE      OPERATOR      COMMENTS

LEAK DETECTION

L.SH-008	Leak Detector Sensor/ Switch @ Manhole L-008	Perform functional verification	Test 1 - Leak alarm appears on PanelView when sensor is immersed in water; north and south extraction wells shut down; autodialer calls out	Test 1 = Did alarm appear on PanelView when sensor was immersed in water?  Did autodialer call out? _____					
L.SH-009	Leak Detector Sensor/ Switch @ Manhole L-009	Perform functional verification	Test 1 - Leak alarm appears on PanelView when sensor is immersed in water; south extraction wells shut down; autodialer calls out	Test 1 = Did alarm appear on PanelView when sensor was immersed in water?  Did autodialer call out? _____					
L.SH-010	Leak Detector Sensor/ Switch @ Manhole L-010	Perform functional verification	Test 1 - Leak alarm appears on PanelView when sensor is immersed in water; south extraction wells shut down; autodialer calls out	Test 1 = Did alarm appear on PanelView when sensor was immersed in water?  Did autodialer call out? _____					

Reviewer \_\_\_\_\_ Date \_\_\_\_\_

**CP2-ER-0046-F37**  
**NORTHWEST PLUME GROUNDWATER SYSTEM**  
**FOURTH QUARTER ODD YEAR**  
**QUARTERLY CALIBRATION AND TESTING TASKS**

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL (YES OR NO)</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
L.SH-011	Leak Detector Sensor/ Switch @ Manhole L- 011	Perform functional verification	Test 1 - Leak alarm appears on PanelView when sensor is immersed in water; south extraction wells shut down; autodialer calls out	Test 1 = Did alarm appear on PanelView when sensor was immersed in water? _____ Did autodialer call out? _____				
L.SH-012	Leak Detector Sensor/ Switch @ Manhole L- 012	Perform functional verification	Test 1 - Leak alarm appears on PanelView when sensor is immersed in water; south extraction wells shut down; autodialer calls out	Test 1 = Did alarm appear on PanelView when sensor was immersed in water? _____ Did autodialer call out? _____				

Reviewer \_\_\_\_\_ Date \_\_\_\_\_

**CP2-ER-0046-F37  
NORTHWEST PLUME GROUNDWATER SYSTEM  
FOURTH QUARTER ODD YEAR  
QUARTERLY CALIBRATION AND TESTING TASKS**

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL (YES OR NO)</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
<b><u>LEVEL DEVICES</u></b>								
L5H/L5L- E301	Level Switch High/Low @ Air Stripper	Perform functional verification	Test 1 - Alarm appears on PanelView when sump level = 95% +/- 5% Test 2 - Alarm appears on PanelView when sump level = 5% +/- 1%	Test 1 = _____ % Test 2 = _____ %				
L5L/L5H- J016	Level Switch Low / High @ Treatment System Sump	Perform functional verification	Test 1 - Sump pump J-016 starts on sump level = 16 inches +/- 2 inches (low level switch) Test 2 - Sump pump J-016 stops on sump level = 5 inches +/- 2 inches (high level switch)	Test 1 = _____ inches Test 2 = _____ inches				
L5L/L5H/ L5HH- F001	Level Switch Low / High- High @ Equalization Tank	Perform functional verification	Test 1a - Low point = 5% +/- 1% and equalization pump J-005 shuts down Test 1b - Equalization pump J-005 restarts when tank raises to 50% +/- 5% Test 2a - At 80% level in EQ tank, alarm on panel view Test 2b - At 80% level in EQ tank, alarm on panel view, all enabled pumps are turned off and all enabled wells restart at 75% Test 2c - High-high switch activates at 98% +/- 2%; alarm appears on PanelView, and equalization pump J-005 shuts down	Test 1a = _____ % Test 1b = _____ % Test 2a = _____ % Test 2b = _____ % Test 2c = _____ %				

Reviewer \_\_\_\_\_ Date \_\_\_\_\_

**CP2-ER-0046-F37  
NORTHWEST PLUME GROUNDWATER SYSTEM  
FOURTH QUARTER ODD YEAR  
QUARTERLY CALIBRATION AND TESTING TASKS**

<u>P&amp;ID</u>	<u>ITEM</u>	<u>TASK</u>	<u>PASS/FAIL CRITERIA</u>	<u>READINGS</u>	<u>PASS/FAIL (YES OR NO)</u>	<u>DATE</u>	<u>OPERATOR</u>	<u>COMMENTS</u>
LSSL/LS H/LSL/LS HH-F002	Level Switch Low-Low / High / Low / High-High @ Backwash / Sluice Tank	Perform functional verification	Test 1 - Backwash pump J-008 stops when the backwash tank level reaches 5% +/- 2% (low-low switch) Test 2a - UV-50 opens and UV-110 closes when the backwash tank reaches 90% +/- 2% (high switch) Test 2b - UV-050 closes and UV-110 opens when the backwash tank reaches 80% +/- 2% (low switch) Test 3 - System shutdown occurs when the backwash tank reaches 98% +/- 2% (high-high switch); alarm appears on PanelView	Test 1 = _____ % Test 2a = _____ % Test 2b = _____ % Test 3 = _____ %				
LSL/LSH/ LSHH- F008	Level Switch Low / High / High-High @ Settling Tank	Perform functional verification	Test 1 - Backwash pump J-008 stops when settling tank level = 95% +/- 2% (high-high level switch)	Test 1 = _____ %				

**INTERLOCKS**

I-20	Interlock	Perform functional verification	Test 1 - During the course of a system shutdown, the air stripper pump J-006 shuts down when the air stripper sump level reaches 10% +/- 2%.	Test 1 = _____ %				
------	-----------	---------------------------------------	--	------------------	--	--	--	--

Reviewer \_\_\_\_\_ Date \_\_\_\_\_



CP2-ER-0046-F37  
 NORTHWEST PLUME GROUNDWATER SYSTEM  
 FOURTH QUARTER ODD YEAR  
 QUARTERLY CALIBRATION AND TESTING TASKS

P&ID      ITEM      TASK      PASS/FAIL CRITERIA      READINGS      PASS/FAIL (YES OR NO)      DATE      OPERATOR      COMMENTS

ALARM CONDITIONS

A-1	Alarm Condition 1	Perform functional verification	Test 1 - Equalization tank pump J-005 stops on system shutdown, alarm appears on PanelView, autodialer calls out	Test 1 = Did alarm appear on PanelView?  Did the autodialer call out?					
A-2	Alarm Condition 2	Perform functional verification	Test 1 - System shuts down when sump level = 21 inches +/- 2 inches (high-high level switch); alarm appears on PanelView; autodialer calls out. Test 2 - System shuts down when trailer sump is full; alarm appears on PanelView; autodialers calls out	Tests 1 and 2 = Did alarm appear on PanelView?  Did the autodialer call out?					
A-3	Alarm Condition 3	Perform functional verification	Test 1 - Leak alarm appears on PanelView when sensor is immersed in water; extraction wells shut down; autodialer calls out	Test 1 = Did alarm appear on PanelView when the LSH-008 sensor was immersed in water?  Did the autodialer call out?					

Reviewer \_\_\_\_\_ Date \_\_\_\_\_